

From: Doll, Laura  
Sent: 6/10/2014 7:02:49 PM  
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Paul  
Clanon (paul.clanon@cpuc.ca.gov); Denise Tyrrell (denise.tyrrell@cpuc.ca.gov);  
Terrie D.' Prosper (terrie.prosper@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fwd: CPUC and DOT Reportable Gas Incident - San Francisco  
FYI.  
Laura

Sent from my iPhone

Begin forwarded message:

**From:** [Redacted]  
**Date:** June 10, 2014 at 6:21:55 PM PDT  
**To:** UO EP Gas Incident Notify  
<DCSTSGasIncidentNotify@exchange.pge.com>  
**Cc:** [Redacted], "Tom, William (Gas Svc Spvr)"  
<WMT1@pge.com>, [Redacted]  
**Subject: CPUC and DOT Reportable Gas Incident - San Francisco**

PG&E received a call at 15:31 hours from the San Francisco Fire Department regarding a release of gas and structure fire. GSR arrived on site at 15:45 hours. The Fire Department had shut off the flow of gas prior to the arrival of the GSR. According to the Fire Department, witness statements indicate the release of gas was caused by vandalism. The regulator on the three meter manifold was found to have a 2-inch hole in it and has been retained as evidence. The source of ignition is unknown. It is estimated that damages to the structure by the meter set exceed \$50,000 making this incident reportable to the CPUC and DOT. There were no injuries or fatalities.

Please let me know if you have any questions regarding this incident.

[Redacted]

PG&E - Gas Operations, Regulatory Compliance

Redacted