

From: Cherry, Brian K
Sent: 7/7/2014 2:00:59 PM
To: Sandoval, Catherine J.K. (CatherineJ.K.Sandoval@cpuc.ca.gov)
(CatherineJ.K.Sandoval@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: Sparking PG&E electric line by [Redacted]

Catherine – FYI. The sparking you reported has been fixed. The circuit was washed and cleaned. Let me know if you see any improvement next time you are out at [Redacted] Geisha wanted to thank you for reporting it and I thank you too.

Brian

From: Williams, Geisha
Sent: Monday, July 07, 2014 1:44 PM
To: Cherry, Brian K
Subject: Fwd: Sparking PG&E electric line by [Redacted]

Brian,

Please thank Comm Sandoval for reporting this situation and let her know the action we have taken.

Geisha

Begin forwarded message:

From: "Swanson, Michael" <MES1@pge.com>
Date: July 7, 2014 at 12:19:41 PM PDT
To: "Hogan, Patrick" <P1HF@pge.com>
Cc: "Williams, Geisha" <GJWD@pge.com>, "Kiraly, Gregory" <GKK6@pge.com>
Subject: RE: Sparking PG&E electric line by [Redacted]

Pat,

Thursday July 3rd, 90 pole locations were washed on the K-1101 circuit, including the location at the Redacted

Let me know if we have further reports of issues at this location.

Mike