




Redacted

Legend

- Gas Station within City Limits
- Gas Transmission Pipeline >60 psi
-  City of Interest
-  Other Cities or Unincorporated
-  San Mateo County Boundary

Service Layer Credits: ESRI, DeLorme, NAVTEQ, USGS, Intermap, iPC, METI, TomTom, San Mateo County GIS



1 in = 0.4 miles

**Foster City
San Mateo County
Pipeline and Station Location Map**





PG&E Critical Infrastructure Information
Must be held in confidence
Facilities to be operated by PG&E personnel only
Pipeline location is not exact
Call 811 before you dig



Redacted

Legend

Pipe Diameter

-  Less than 10 in.
-  10 - 18 in.
-  20 - 28 in.
-  30 - 38 in.



City of Interest



Other Cities or Unincorporated



San Mateo County Boundary

Service Layer Credits: ESRI, DeLorme, NAVTEQ, USGS, Intermap, iPC, METI, TomTom, San Mateo County GIS

PG&E Critical Infrastructure Information

Must be held in confidence
Facilities to be operated by PG&E personnel only
Pipeline location is not exact
Call 811 before you dig

Legend

Pipe Install Date

-  1970's
-  1980's
-  1990's
-  2000's
-  2010's
-  1920's
-  1930's
-  1940's
- 1950's
- 1960's



Hydrotest Performed



City of Interest



Other Cities or Unincorporated



San Mateo County Boundary

**Foster City, San Mateo County
Transmission Pipeline >60 psi
Diameter, Install Date and Hydrotest Maps**



1 in = 0.4 miles






Redacted

Legend

Pipe Class

Study Area is 220 yards on either side of the pipeline centerline for a continuous 1-mile length

-  Class 1
-  Class 2
-  Class 3
-  Class 4

-  City of Interest
-  Other Cities or Unincorporated
-  San Mateo County Boundary





Class Descriptions




- Class 1:** 0 - 10 buildings intended for human occupancy
- Class 2:** 11 - 45 buildings intended for human occupancy
- Class 3:** 46+ buildings intended for human occupancy or an area in close proximity to public place of assembly (e.g. playground, recreation area, etc.)
- Class 4:** 4+ story buildings are prevalent

Service Layer Credits: ESRI, DeLorme, NAVTEQ, USGS, Intermap, IPC, METI, TomTom, San Mateo County GIS

Legend

Pipe MAOP

-  90 - 140 psi
-  145 - 180 psi
-  230 - 300 psi
-  365 - 400 psi

-  City of Interest
 -  Other Cities or Unincorporated
 -  San Mateo County Boundary
- MAOP = Maximum Allowable Operating Pressure

PG&E Critical Infrastructure Information
Must be held in confidence
Facilities to be operated by PG&E personnel only
Pipeline location is not exact
Call 811 before you dig

**Foster City, San Mateo County
Transmission Pipeline >60 psi
Class Location and MAOP Maps**



1 in = 0.4 miles

