

From: Sandoval, Catherine J.K.
Sent: 7/7/2014 2:06:59 PM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7);
Baker, Amy C. (amy.baker@cpuc.ca.gov); Katague, Ditas
(ditas.katague@cpuc.ca.gov)

Cc:

Bcc:

Subject: Re: Sparking PG&E electric line by [Redacted]

Thanks for your prompt follow-up and report on the actions taken for the lines by [Redacted].
Geisha shared that since there's been less rain than usual, this problem may have appeared sooner
than usual. Geisha said that issues like this are more often seen in the fall after a dry summer.
Is 90 poles a usual number to wash? Interested to learn more.
Thanks again and I'll feel better now staying @ the [Redacted].
Thanks, Commissioner Sandoval

From: Cherry, Brian K [BKC7@pge.com]
Sent: Monday, July 07, 2014 2:00 PM
To: Sandoval, Catherine J.K.
Subject: FW: Sparking PG&E electric line by Seal Rock Inn

Catherine – FYI. The sparking you reported has been fixed. The circuit was washed
and cleaned. Let me know if you see any improvement next time you are out at
[Redacted]. Geisha wanted to thank you for reporting it and I thank you too.

Brian

From: Williams, Geisha
Sent: Monday, July 07, 2014 1:44 PM
To: Cherry, Brian K
Subject: Fwd: Sparking PG&E electric line by [Redacted]

Brian,

Please thank Comm Sandoval for reporting this situation and let her know the action we have
taken.

Geisha

Begin forwarded message:

From: "Swanson, Michael" <MESI@pge.com>
Date: July 7, 2014 at 12:19:41 PM PDT
To: "Hogan, Patrick" <PIHF@pge.com>
Cc: "Williams, Geisha" <GJWD@pge.com>, "Kiraly, Gregory" <GKK6@pge.com>
Subject: RE: Sparking PG&E electric line by [Redacted]

Pat,

Thursday July 3rd, 90 pole locations were washed on the K-1101 circuit, including the location at the [Redacted]

Let me know if we have further reports of issues at this location.

Mike

PG&E is committed to protecting our customers' privacy.
To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>