

From: Cherry, Brian K
Sent: 8/24/2014 11:19:13 AM
To: mp6@cpuc.ca.gov (mp6@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: Reportable Gas Incident - Earthquake in Napa County

FYI

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: "Chang, Charles" <CYC8@pge.com>
Date: August 24, 2014 at 11:06:06 AM PDT
To: UO EP Gas Incident Notify
<DCSTSGasIncidentNotify@exchange.pge.com>
Cc: "Wong, Daniel (GE&O)" <D2WN@pge.com>, "Barlow, Joe"
<J6B5@pge.com>, "Miramontez, Nancy" <NWM1@pge.com>, Gas Ops
A&RM Regulatory Compliance <GasOpsSPRegulatoryCompliance@pge.com>,
"Holtkamp, Philipp" <PEHE@pge.com>, "Souza, Kevin F" <KFS8@pge.com>,
"Harden, Lorene R" <LRW5@pge.com>
Subject: Reportable Gas Incident - Earthquake in Napa County

At approximately 0320 hours on August 24, 2014, a magnitude 6.0 earthquake struck the Napa County area. PG&E has received and responded to customer odor calls and calls from Fire and Police agencies throughout the morning. PG&E has confirmed and remediated damages to a number of service risers at addresses throughout the Napa area (approximately 5 instances as of the time of this notification). No major outages in natural gas delivery have been confirmed. No injuries or fatalities resulting from issues with PG&E gas facilities have been confirmed. PG&E is reporting this to the DOT and the CPUC based on operator judgment of the significance of this event.

Charles Chang

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

6111 Bollinger Canyon Rd, BR1Y4B, San Ramon, CA 94583

Office (925) 328-5727

Mobile (925) 323-7773