

From: Cherry, Brian K
Sent: 8/24/2014 11:20:35 AM
To: Michel Peter Florio (MichelPeter.Florio@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: American Canyon Earthquake Update

FYI. Updated

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: "Allen, Meredith" <MEAe@pge.com>
Date: August 24, 2014 at 11:10:34 AM PDT
To: "Cherry, Brian K" <BKC7@pge.com>
Subject: Re: American Canyon Earthquake Update

Brian,

Here is updated information. Next update at 13:00.

Thanks,
Meredith

- Current electric outage: 22,000 customers
- 21 of 34 identified substations inspected and no damage reported, remaining inspections expected to be complete this afternoon
- Gas transmission leak survey complete and no leaks detected
- 6 inch gas main was not a rupture. It is a grade 3 leak.
- Distribution gas leaks surveys ongoing and Picarro to be mobilized in critical areas
- Mutual aid not anticipated

On Aug 24, 2014, at 8:46 AM, "Allen, Meredith"

<MEAc@pge.com> wrote:

Below is update.

Thanks,

Meredith

- No employee injuries or public injuries related to our facilities
- Initial electric outage: 64,000 customers
- Current electric outage: 26,000 customers
- No electric and gas transmission impacts
- Conducting inspections of substations
- Conducting gas distribution leak surveys and mobilizing Picarro vehicle
- 1 6 inch gas line rupture: crews onsite
- Multiple gas service line leaks to small businesses and residences