

From: Cherry, Brian K  
Sent: 8/24/2014 11:21:22 AM  
To: Denise Tyrrell (denise.tyrrell@cpuc.ca.gov); Liza Malashenko (elizaveta.malashenko@cpuc.ca.gov); Paul Clanon (paul.clanon@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fwd: American Canyon Earthquake Update

FYI. Updated

Brian K. Cherry  
PG&E Company  
VP, Regulatory Relations  
77 Beale Street  
San Francisco, CA. 94105  
(415) 973-4977

Begin forwarded message:

**From:** "Allen, Meredith" <MEAe@pge.com>  
**Date:** August 24, 2014 at 11:10:34 AM PDT  
**To:** "Cherry, Brian K" <BKC7@pge.com>  
**Subject: Re: American Canyon Earthquake Update**

Brian,

Here is updated information. Next update at 13:00.

Thanks,  
Meredith

- Current electric outage: 22,000 customers
- 21 of 34 identified substations inspected and no damage reported, remaining inspections expected to be complete this afternoon
- Gas transmission leak survey complete and no leaks detected
- 6 inch gas main was not a rupture. It is a grade 3 leak.
- Distribution gas leaks surveys ongoing and Picarro to be mobilized in critical areas
- Mutual aid not anticipated

On Aug 24, 2014, at 8:46 AM, "Allen, Meredith"  
<[MEAe@pge.com](mailto:MEAe@pge.com)> wrote:

Below is update.

Thanks,

Meredith

- No employee injuries or public injuries related to our facilities
- Initial electric outage: 64,000 customers
- Current electric outage: 26,000 customers
- No electric and gas transmission impacts
- Conducting inspections of substations
- Conducting gas distribution leak surveys and mobilizing Picarro vehicle
- 1 6 inch gas line rupture: crews onsite
- Multiple gas service line leaks to small businesses and residences