

From: Cherry, Brian K
Sent: 8/24/2014 3:17:08 PM
To: mp6@cpuc.ca.gov (mp6@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: Update

FYI

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: "Allen, Meredith" <ME Ae@pge.com>
Date: August 24, 2014 at 2:56:40 PM PDT
To: "Cherry, Brian K" <BKC7@pge.com>
Subject: Update

Brian,

Below is update from last call. Next call at 4:00.

Thanks,
Meredith

- Electric Outages: 16,000 customers, 57,000 customers restored.
 - Substation: Inspections 100% complete. Found minor damage to substation in Napa. Will not impact ability to serve customers.
 - Electric Transmission Patrols: Complete, no issues
- Gas Distribution: Leak surveys will be complete by 4:00. Finding minimal issues. Plan to recheck areas with Picarro Supercrew this week.
Gas Transmission: Recheck should be complete shortly.