

From: Cherry, Brian K  
Sent: 8/24/2014 3:17:28 PM  
To: carla.peterman@cpuc.ca.gov (carla.peterman@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fwd: Update

FYI

Brian K. Cherry  
PG&E Company  
VP, Regulatory Relations  
77 Beale Street  
San Francisco, CA. 94105  
(415) 973-4977

Begin forwarded message:

**From:** "Allen, Meredith" <ME Ae@pge.com>  
**Date:** August 24, 2014 at 2:56:40 PM PDT  
**To:** "Cherry, Brian K" <BKC7@pge.com>  
**Subject:** Update

Brian,

Below is update from last call. Next call at 4:00.

Thanks,  
Meredith

- Electric Outages: 16,000 customers, 57,000 customers restored.
  - Substation: Inspections 100% complete. Found minor damage to substation in Napa. Will not impact ability to serve customers.
  - Electric Transmission Patrols: Complete, no issues
- Gas Distribution: Leak surveys will be complete by 4:00. Finding minimal issues. Plan to recheck areas with Picarro Supercrew this week.
- Gas Transmission: Recheck should be complete shortly.