

From: Allen, Meredith
Sent: 8/24/2014 8:42:21 PM
To: Terrie D. Prosper (terrie.prosper@cpuc.ca.gov)
Cc: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)
Bcc:
Subject: RE: Update

Terrie,

Below is the latest information.

Thanks,
Meredith

- Electric Outages: 6,800 customers, expect majority to be restored by midnight. For those customers that may not be restored by that time, we will be following up with them over next hour.
- Base Camp - operational at Napa Airport providing meals and work packages
- Preliminary Electric Damage:
 - 4 poles (3 replaced)
 - 6 transformers (3 repaired)
 - 176 Services (all but 1 fixed)
 - 12 cross arms (8 replaced)
 - 5,000 feet of primary wire (nearly 3,000 feet replaced)

On Aug 24, 2014, at 4:41 PM, "Allen, Meredith" <MEAe@pge.com> wrote:

Terrie,

A few updates below.

Thanks,
Meredith

- The electric outage is now 7,800 customers.
- Gas Distribution foot survey with standard leak survey equipment has currently not detected any GD main leaks. We expect to complete remaining surveys shortly.
- Picarro vehicle is currently inspecting Napa business district for leaks.
- We expect to issue another news release between 5-6

On Aug 24, 2014, at 3:28 PM, "Allen, Meredith" <MEAc@pge.com> wrote:

Terrie,
Here is the latest. Please let me know if you need additional information. We will continue to send you updates.

Thanks,
Meredith

- Electric Outages: 16,000 customers, 57,000 customers restored.
We plan to restore the majority of customers today. Certain customers may require more time and we will communicate with those customers directly.

- Substation: Inspections 100% complete. Found minor damage to substation in Napa. Will not impact ability to serve customers.

- Electric Transmission Patrols: Complete, no issues

Gas Distribution: Leak surveys will be complete by 4:00. Finding minimal issues. Plan to recheck areas with Picarro Supercrew this week.

Gas Transmission: Recheck should be complete shortly.