

From: Prosper, Terrie D.  
Sent: 8/24/2014 8:43:32 PM  
To: Allen, Meredith (/O=PG&E/OU=Corporate/cn=Recipients/cn=MEAe)  
Cc: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)  
Bcc:  
Subject: RE: Update

Thank you!

---

From: Allen, Meredith [MEAe@pge.com]  
Sent: Sunday, August 24, 2014 8:42 PM  
To: Prosper, Terrie D.  
Cc: Cherry, Brian K  
Subject: Re: Update

Terrie,

Below is the latest information.

Thanks,  
Meredith

- Electric Outages: 6,800 customers, expect majority to be restored by midnight. For those customers that may not be restored by that time, we will be following up with them over next hour.
- Base Camp - operational at Napa Airport providing meals and work packages
- Preliminary Electric Damage:
  - 4 poles (3 replaced)
  - 6 transformers (3 repaired)
  - 176 Services (all but 1 fixed)
  - 12 cross arms (8 replaced)
  - 5,000 feet of primary wire (nearly 3,000 feet replaced)

On Aug 24, 2014, at 4:41 PM, "Allen, Meredith" <MEAe@pge.com<<mailto:MEAe@pge.com>>> wrote:

Terrie,

A few updates below.

Thanks,  
Meredith

- The electric outage is now 7,800 customers.
- Gas Distribution foot survey with standard leak survey equipment has currently not detected any GD main leaks. We expect to complete remaining surveys shortly.
- Picarro vehicle is currently inspecting Napa business district for leaks.
- We expect to issue another news release between 5-6

On Aug 24, 2014, at 3:28 PM, "Allen, Meredith" <MEAe@pge.com<<mailto:MEAe@pge.com>>> wrote:

Terrie,

Here is the latest. Please let me know if you need additional information. We will continue to send you updates.

Thanks,  
Meredith

- Electric Outages: 16,000 customers, 57,000 customers restored. We plan to restore the majority of customers today. Certain customers may require more time and we will communicate with those customers directly.
- Substation: Inspections 100% complete. Found minor damage to substation in Napa. Will not impact ability to serve customers.
- Electric Transmission Patrols: Complete, no issues
- Gas Distribution: Leak surveys will be complete by 4:00<x-apple-data-detectors://1>. Finding minimal issues. Plan to recheck areas with Picarro Supercrew this week.
- Gas Transmission: Recheck should be complete shortly.

PG&E is committed to protecting our customers' privacy.

To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>