

From: Cherry, Brian K
Sent: 8/24/2014 9:08:36 AM
To: Catherine J. K. Sandoval (CatherineJ.K.Sandoval@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: American Canyon Earthquake Update

FYI

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: "Allen, Meredith" <MEAe@pge.com>
Date: August 24, 2014 at 8:46:31 AM PDT
To: "Cherry, Brian K" <BKC7@pge.com>
Subject: American Canyon Earthquake Update

Brian,

Below is update.

Thanks,
Meredith

- No employee injuries or public injuries related to our facilities
- Initial electric outage: 64,000 customers
- Current electric outage: 26,000 customers
- No electric and gas transmission impacts
- Conducting inspections of substations
- Conducting gas distribution leak surveys and mobilizing Picarro vehicle
- 1 6 inch gas line rupture: crews onsite
- Multiple gas service line leaks to small businesses and residences