

From: Prosper, Terrie D.
Sent: 8/24/2014 4:52:09 PM
To: Allen, Meredith (/O=PG&E/OU=Corporate/cn=Recipients/cn=MEAe)
Cc: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)
Bcc:
Subject: RE: Update

Thank you!

----- Original message -----

From: "Allen, Meredith"
Date:08/24/2014 4:41 PM (GMT-08:00)
To: "Prosper, Terrie D."
Cc: "Cherry, Brian K"
Subject: Re: Update

Terrie,

A few updates below.

Thanks,
Meredith

- The electric outage is now 7,800 customers.
- Gas Distribution foot survey with standard leak survey equipment has currently not detected any GD main leaks. We expect to complete remaining surveys shortly.
- Picarro vehicle is currently inspecting Napa business district for leaks.
- We expect to issue another news release between 5-6

On Aug 24, 2014, at 3:28 PM, "Allen, Meredith" <MEAe@pge.com<mailto:MEAe@pge.com>> wrote:

Terrie,

Here is the latest. Please let me know if you need additional information. We will continue to send you updates.

Thanks,
Meredith

- Electric Outages: 16,000 customers, 57,000 customers restored. We plan to restore the majority of customers today. Certain customers may require more time and we will communicate with those customers directly.
- Substation: Inspections 100% complete. Found minor damage to substation in Napa. Will not impact ability to serve customers.
- Electric Transmission Patrols: Complete, no issues
- Gas Distribution: Leak surveys will be complete by 4:00<x-apple-data-detectors://1>. Finding minimal issues. Plan to recheck areas with Picarro Supercrew this week.
- Gas Transmission: Recheck should be complete shortly.

PG&E is committed to protecting our customers' privacy.

To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>