

From: Cherry, Brian K  
Sent: 8/24/2014 11:18:45 AM  
To: Michael R. Peevey (michael.peevey@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fwd: Reportable Gas Incident - Earthquake in Napa County

FYI

Brian K. Cherry  
PG&E Company  
VP, Regulatory Relations  
77 Beale Street  
San Francisco, CA. 94105  
(415) 973-4977

Begin forwarded message:

**From:** [Redacted]  
**Date:** August 24, 2014 at 11:06:06 AM PDT  
**To:** UO EP Gas Incident Notify  
<DCSTSGasIncidentNotify@exchange.pge.com>  
**Cc:** [Redacted]  
[Redacted] Gas Ops  
A&RM Regulatory Compliance <GasOpsSPRegulatoryCompliance@pge.com>,  
[Redacted]  
[Redacted]  
**Subject: Reportable Gas Incident - Earthquake in Napa County**

At approximately 0320 hours on August 24, 2014, a magnitude 6.0 earthquake struck the Napa County area. PG&E has received and responded to customer odor calls and calls from Fire and Police agencies throughout the morning. PG&E has confirmed and remediated damages to a number of service risers at addresses throughout the Napa area (approximately 5 instances as of the time of this notification). No major outages in natural gas delivery have been confirmed. No injuries or fatalities resulting from issues with PG&E gas facilities have been confirmed. PG&E is reporting this to the DOT and the CPUC based on operator judgment of the significance of this event.

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

Redacted