

From: Cherry, Brian K
Sent: 8/24/2014 11:19:23 AM
To: carla.peterman@cpuc.ca.gov (carla.peterman@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: Reportable Gas Incident - Earthquake in Napa County
FYI

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: Redacted
Date: August 24, 2014 at 11:06:06 AM PDT
To: UO EP Gas Incident Notify
<DCSTSGasIncidentNotify@exchange.pge.com>
Cc: Redacted, Redacted
Redacted "Redacted" Gas Ops
A&RM Regulatory Compliance <GasOpsSPRegulatoryCompliance@pge.com>,
Redacted Redacted
Redacted
Subject: Reportable Gas Incident - Earthquake in Napa County

At approximately 0320 hours on August 24, 2014, a magnitude 6.0 earthquake struck the Napa County area. PG&E has received and responded to customer odor calls and calls from Fire and Police agencies throughout the morning. PG&E has confirmed and remediated damages to a number of service risers at addresses throughout the Napa area (approximately 5 instances as of the time of this notification). No major outages in natural gas delivery have been confirmed. No injuries or fatalities resulting from issues with PG&E gas facilities have been confirmed. PG&E is reporting this to the DOT and the CPUC based on operator judgment of the significance of this event.

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

Redacted