

From: Cherry, Brian K
Sent: 8/24/2014 11:19:32 AM
To: Catherine J. K. Sandoval (CatherineJ.K.Sandoval@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: Reportable Gas Incident - Earthquake in Napa County

FYI

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: [Redacted]
Date: August 24, 2014 at 11:06:06 AM PDT
To: UO EP Gas Incident Notify
<DCSTSGasIncidentNotify@exchange.pge.com>
Cc: [Redacted], [Redacted]
[Redacted], [Redacted] Gas Ops
A&RM Regulatory Compliance <GasOpsSPRegulatoryCompliance@pge.com>, [Redacted]
[Redacted]
"Harden, Lorene R" <LRW5@pge.com>
Subject: Reportable Gas Incident - Earthquake in Napa County

At approximately 0320 hours on August 24, 2014, a magnitude 6.0 earthquake struck the Napa County area. PG&E has received and responded to customer odor calls and calls from Fire and Police agencies throughout the morning. PG&E has confirmed and remediated damages to a number of service risers at addresses throughout the Napa area (approximately 5 instances as of the time of this notification). No major outages in natural gas delivery have been confirmed. No injuries or fatalities resulting from issues with PG&E gas facilities have been confirmed. PG&E is reporting this to the DOT and the CPUC based on operator judgment of the significance of this event.

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

Redacted