

From: Allen, Meredith  
Sent: 8/25/2014 10:42:23 AM  
To: Cho, Raymond (Raymond.Cho@cpuc.ca.gov) (Raymond.Cho@cpuc.ca.gov);  
TerKeurst, Charlotte (charlotte.terkeurst@cpuc.ca.gov)  
(charlotte.terkeurst@cpuc.ca.gov); Daye, Fadi (fadi.daye@cpuc.ca.gov)  
(fadi.daye@cpuc.ca.gov)  
Cc: Back, Eric (ET) (/O=PG&E/OU=Corporate/cn=Recipients/cn=EWB8); Redact  
Redacted  
Bcc:  
Subject: American Canyon/Napa Earthquake Update

Charlotte, Fadi, Raymond,

Yesterday we activated our EOC, 2 OECs and an REC in response to the American Canyon/Napa earthquake. We also had a base camp at the Napa Airport that was providing meals and work packages.

The unplanned outages were 87,445 customers for the Entire EO System, 50,135 for North Bay and 27,683 for Sonoma with a combined total of 77,818 customers for NB and Sonoma. These numbers are preliminary and may change.

Currently, we have 57 customers that remain without electricity on four outages with ETORs of later this morning.

Yesterday, we inspected 31 substations and found no issues except for minor damage at Napa substation. We also patrolled multiple electric transmission lines and found no issues. The damage was primarily on the overhead distribution system.

We deactivated the EOC this morning.

We had no employee injuries involved with our response and received no reports of public injury due to our facilities.

Please let us know if you have question or would like additional information.

Thanks,

Meredith