

From: Doll, Laura  
Sent: 9/5/2014 1:42:48 PM  
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Terrie D.' Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: FW: CPUC Reportable Incident - Carmel by the Sea

FYI – 3<sup>rd</sup> party contractor dig-in in Carmel.

**From:** Redacted  
**Sent:** Friday, September 05, 2014 1:39 PM  
**To:** UO EP Gas Incident Notify  
**Cc:** Redacted  
**Subject:** RE: CPUC Reportable Incident - Carmel by the Sea

Correction – There were NO injuries.

Redacted

**From:** Redacted  
**Sent:** Friday, September 05, 2014 1:36 PM  
**To:** UO EP Gas Incident Notify  
**Cc:** Redacted  
**Subject:** CPUC Reportable Incident - Carmel by the Sea

At approx. 1150 hrs on 9/5, PG&E was notified of a third-party dig-in at the south-west corner of 11th and Camino Real in Carmel by the Sea. The third-party, Monterey Peninsula Engineering, was digging a joint trench for new business trying to expose the main, when they struck and pulled off the stub on 3" plastic pipe, creating an unintentional release of gas. Foreman states there is a USA ticket (ticket number is unknown at this time). Both FD and PD are onsite and along with the PG&E crew that arrived onsite at approx. 12:26 hrs, they evacuated 4 buildings, one of which was the Sea View Bed and Breakfast (approx. 10 ppl were inside hotel).

The stub has a two way feed and PG&E crews have squeezed one. Estimated time for shut-in is approx. 1330 hrs.

There were injuries, damage is not likely to exceed \$50k, and media is not onsite at the moment. This incident is being reported on operator judgment.

Redacted