

Monthly Odorization Report

Electronic Display Odorizers

	A	B	C
1	* Use this on-line form to fill in true reads. Odorization rate will auto-calculate.		
2	DAY	Odorant	Accumulated
3		Injected (lbs)	Flow (MMscf)
4	1		
5	2		
6	3		
7	4		
8	5		
9	6		
10	7		
11	8		
12	9		
13	10		
14	11		
15	12		
16	13		
17	14		
18	15		
19	16		
20	17		
21	18		
22	19		
23	20		
24	21		
25	22		
26	23		
27	24		
28	25		
29	26		
30	27		
31	28		
32	29		
33	30		
34	31		
35		0	0
36		Previous Tank Volume	
37		Odorant Injected	
38		Current Tank Volume (gal)	
39			
40			
41			
42		Date: _____	
43		Line: _____	
44		Station: _____	
45		Tank Capacity: _____ gals	
46			
47	Odorant density for 50/50 (THT/TBM) blend = 7.45 lb/gal		
48	Conduct odor intensity test once per month. Odorant density for 50/50 (THT/TBM) blend = 7.45 lb/gal		
49	Send original completed forms to: GT&D Station Engineering, 375 No. Wiget Ln, Walnut Creek		
50	*A copy of the completed form must be kept in the district/division for at least 5 years.		



Monthly Odorization Report
Electronic Display Odorizers

	D	E	F
1			
2			
3	Odorization		
4	Rate (lb/MMscf)	Comments	Completed By
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35	* 0.00		
36			
37	123	galons (from previous month)	
38	0	galons (lbs. / 7.45 = gals)	
39	123	galons _____, percentage _____	<i>(check one)</i>
40			
41			
42	Odor Intensity Reading: _____ % gas in air		
43	Sniff Test Location: _____		
44	Monthly Report Ending: _____		
45	Approved by: _____		
46			
47			
48			
49			
50			

