

Sample Battery Database Input Form

BATTERY INFORMATION INPUT FORM

ID	Bank Voltage	Tested Capacity (%)
Location: Tionesta	Float Voltage	Ave Cell Resistance:
Designation: 48 Volt Telecom	Equalize Voltage	Last Discharge Test: 10/2/2002
Manufacturer: C&D	Configuration: series	Next Discharge Test: 1/1/2006
Model: HDL-260	Application: Telecomm	Max Charger Current: 45
Type: VRLA	Load (A): 14.00	Shunt Type: 100/100
Date Installed: 7/10/2001	Cell Warning Limit (V): 1.80	Notes: 2001 = 100% Burney district has decided to put this battery on a five year replacement cycle and forego the annual testing.
Cells/String: 24	Cell Shutdown Limit (V): 1.75	
Strings: 1	Test Discharge Rate (A): 35	
Volts/cell: 2.25	Test Discharge Duration (hrs): 8	
Rated Capacity: 275		

Record: 3 of 3 (Filtered)