

## **District Regulator Station** Maintenance Record (HPR Type)

62-6321A (05/08) Gas Distribution Page 1 of 2

Location	Stage													
Associa	ited FM No(s).													
Run:	Left, Middle, Right, Top, or Bottom (Looking)	Downstream)									Γ			
	_								1		<del>                                     </del>			
	Employee (LAN	Date:			_						<del>                                     </del>			—
<del> </del>										-	_			
	Supervisor (LAN	Date:	_		-								<del></del> -	
		Date:	<u> </u>				<u> </u>	_			<u> </u>		<u> </u>	_
	Task Description	Result												
1F- ·	Are Gauges Calibrated?	y,n												_
IJ1	Piping and Operating Diagrams Accurate	y,n											\	
IJ2	Fire Valve Accessible and Operated	y,n												
IJ3, IJ5	Vault Cover and Surroundings	g,p												
IJ4	U4 Air Test													
U6	Vault Inspection	g,p												
IJ7	Gas Leak Test	p, np												
118, 119	Ventilating System & Relief Stacks	g,p												
U10	Piping and Equipment Condition	g,p								••		4,4		
-1311-	H- Elter-Condition												$\overline{}$	
IJ12	Locking Devices Present And Operational y,n												7	
TYPE OF		B	A B		A B		ΑB		AB		ΑB			
	As Found and As Left Settings		AF	AL	AF	AL	AF	AL	AF	AL	AF	AL	AF	A
IIA4	Regulator Set Point	PSI, W.C.										<u>,-:</u>		<u> </u>
ILA5	Regulator Lockup	y,n		<u> </u>			L							
IIA6a	Monitor Set Point	PSI, W.C.	<u> </u>	<b> </b>					-		-1			<b>⊢</b>
J	Monitor Lockup	y,n									<u>'</u> .		_	L_
IIA6b, X		PSI, W.C.			$\vdash$		<u> </u>				``.		<u> </u>	$\vdash$
11AUL	OPP Upstream or Downstream	U,D	-	<u> </u>	$\vdash$		-		_	L	-		$\leftarrow$	
IIA8,9,10	Programment Clear Vent Lines  Return All Equipment, Valves and Locks to Normal Operation and Position	y,n y,n							<del> </del>				)	_

Enter yes, no; good, poor; pressure; pass, no pass; control loop includes filter, variable restrictor, and tubing; (line out all non-applicable boxes).

On back of this form show any corrective work done, other than inspection and testing:

1. Pressure setting changes and reason

2. Parts replacement and reason

3. Component replacement ("District Regulator Data Sheet" must be updated)

4. Leak repairs or equipment repair

5. Miscellaneous work such as pumping pits, touch-up painting, filter blowdown or cleanout, etc.

6. Valves flushed and/or greased

Material Redacted GTR0054338

<sup>\*</sup> If pre-entry air testing indicates unacceptable results per GiB 280, entry must be conducted in accordance with confined space entry procedures (S4414 and/or S2013)



## District Regulator Station Maintenance Record (HPR Type)

62-6321A (05/08) Gas Distribution Page 2 of 2

Date	Signature	Comments
	1	