

**Attachment 3**

**CHECK LEAK LOG SURVEY FOR: January 98  
PACIFIC GAS AND ELECTRIC COMPANY**

**Division: Central Coast  
PCC: Hollister  
Wall Map: 1**

Leak Number	Address/City	GR	Wall Map	Pist Block	Last Read/Date Read/Location	Date Reported	Compliance Date**	Reading	Inst *	Inst. #	GR	Location/Remarks	Action/Time	Date/Initials	Grade 3 Leak Recheck Interval***
98-XXXXX-Y	1031 Main St Hollister	2	1	3	590 gas in street		11/30/98								
98-XXXXX-Y	1019 Main St Hollister	2	1	2	290 gas in side walk		10/31/98								

Leak Surveyor to complete: Date Rescheduled, Reading, Instrument Type, Instrument #, Grade, Location/Remarks, Action/Time, Date/Initials, and Grade 3 Rechecked Interval.

\*Instrument Type: H - hydrogen flame ionization or C - combustion gas indicator.

\*\*Compliance Date: this is the absolute due date required by CPUC and PG&E Standard Practice.

\*\*\*Enter the # of months for the Grade 3 Leak Recheck Interval, if different from next scheduled survey (e.g., 12, 18, 36 months). If left blank, default will be the next scheduled survey after the current year survey.