

Recheck Leak Log

Rechecks due: By 10/1/2005

Division: Peninsula
District: Peninsula
Wall Map: 3279

Recheck Key 16044

Leak Number	Address/City	Map Plat V* Block	GR	Read (% gas) /		Date Reptd / Date Repair	Due Date Recheck	Read	2% CD	Dwn Via Vent	I.* Ins.#	GR	Location/Remarks	Date Time	GR3 Rchk Interval	Cont Mos	
				2% CD / Date	Read Location												
05200161 1	920 Grand St Redwood Cy	2 G01 010	3279	1	A	2/28/2005 over SVC TEE longside	9/30/2005 7										
05200121 2	862 Cleveland St Redwood Cy	2 G01 023	3279	10		2/28/2005 over main by fence post	9/30/2005 7										
05200071 3	522 Cleveland St Redwood Cy	2 G01 026	3279	4		2/23/2005 reading over valve @ main	9/30/2005 7										
04200491 ** 4	1122 Cleveland St Redwood Cy	3 G01 V 051	3279	3		2/9/2005 Under sidewalk near main	6/30/2005 4										
05200141 5	715 Madison Ave Redwood Cy	2 G01 074	3279	4		2/28/2005 over SVC TEE @ main	9/30/2005 7										

Leak Surveyor to complete: Reading, 2% or Less code. Downgrade Via Ventilation, Instrument Type, Instrument #, Grade, Location/Remarks, Date & Time Rechecked, Initials, Grade 3 Recheck Interval and Continue 4 Months. **Venting Flag (V*):** A "V" will display below the previous grade if this leak is being rechecked at 4 month intervals due to a previous downgrade via ventilation.

Due Date: This is the absolute due date required by CPUC and PGE Standard Practices.

Instrument Type (I*): H - hydrogen flame ionization or C - combustion gas indicator.

Dwn Via Vent: Enter Yes if the leak is downgraded via ventilation or No if not.

Cont 4 Mos: If the leak was downgraded via ventilation at least 12 months ago, enter Yes to continue 4 month recheck intervals or No to discontinue 4 month recheck intervals.

GR3 Rchk Interval: Enter the # of months for the grade 3 leak recheck interval, if different from next scheduled survey (e.g. 12, 18, 36, 60) if left blank, default will be the next scheduled survey after the current year survey.

2% CD: Enter the 2% reason code if the grade is 1, 2+ or 2 and the reading is 2% or less: A-Wall to wall and traveling, B-Next to, at or under building, C-Odor, next to public gathering location, D-In foreign structure, E-Audible and/or visible, F-On facility in extremely poor condition,

G-At least second customer call out, H-Leak is reported as 0% Gas Visual, J-Leak within the scope of work by others, S-Leak is suspected to be on a copper service.

** Aform Printed for this leak. *** Grade 3 downgrade is not allowed.