

## Leak Survey, Repair, Inspection, and Gas Quarterly Incident Report (Form "A")

**62-4060** (Rev 3/08) Gas T&D Utility Standard

2761 Listing Company	TOPOIT (1 O	A <i>j</i>	S4110			
Year Series SFX	IITIAL LEAK DATA ⊨		Month Day Year			
Leak Number — Day Year USA	A Ticket #	Valid Date				
Date Reported - Time Rep	orted (2	4 hr Time) PCC Number				
Response	ne Company	Paved Wall-To-	es No			
Moratorium Expire Date SAP Recheck Order #		SAP Repair Order #				
Address:	City:					
Description of Reading Location:						
REPORTED BY: Call-In Mobile Survey Other Employee	SURFACE OV	<b>/ER LEAK</b> : ☐ Concrete ☐ Asphalt	☐ Unsurfaced ☐ Other			
2% or Less or Via   Vent   Copper   No	DATE	Time (24 hr Time) OPERATOR LAN ID	UNIT SERIAL NUMBER (Last 4 Digits)  LOCATION REMARKS (Not needed, if the same as previous)			
PRIORITY 2+ REQUESTED REPAIR DATE (Only needed if le	ess than 90 days)	- (Repair required w	ithin 90 calendar days)			
<u>a</u> Instrument Type: Enter <u>H</u> for Hydrogen Flame lo	nization, <u>C</u> for Combustib	le Gas Indicator, or <u>V</u> for Visi	ual.			
<ul> <li>b Enter Grade or enter 2+ for Priority Grade 2. Enter 0 (zero) if no leak is found. If a competent first responder from other than M&amp;C determines that the leak is non-hazardous, enter as a Grade 2+. The % Gas will be zero, the instrument will be "V" and the 2% reason code will be "H". Use the next line below to upgrade or downgrade the leak.</li> <li>c 2% or less reason code is required if leak is graded as 1, 2+, or 2:  A-Wall to wall and traveling, B-Next to, at or under building, C-Odor and next to public gathering location, D-In foreign structure, E-Audible and/or visible,</li> <li>F-On facility in extremely poor condition, G-At least second customer call out, H-Leak is reported as 0% Gas Visual, J-Leak within the scope of work by others, S-Leak is suspected to be on a copper service</li> </ul>						
	MAPPING DATA	CVCTE	M PRESSURE (MAOP)			
Leak Location Map Wall Map:			Grade 1, 2, & 2+ Downgrades to Grade 0			
Recorded Location Map Wall Map:	Plat: Blo	<del> </del>	( ≤10.5" WC) SHP( ≤ 25 psig)			
Normally Cathodically Protected Yes No CPA:		(TP only)	<b>1P</b> (≤ 60 psig)			
Year Inst. TP Line #	Mile Post:	Original Job # (TP On	lv)			
		Plastic  Steel Installatio				
	—— PIPE DATA ⊨					
LEAK SOURCE:	LEAK CAUSE:		LINE MATERIAL:			
☐ Bell Joint ☐ SS Fitting in Plastic System	Atmospheric Corrosion	☐ Vehicle	Copper			
☐ Body of Pipe ☐ Valve ☐ Clamp ☐ Unknown	☐ Cast Iron Fracture ☐ Construction Defect	<ul><li>☐ Incorrect Operation</li><li>☐ Equipment Malfunction</li></ul>	☐ Steel/Wrought Iron ☐ Cast/Ductile Iron			
□ Drip □ Other	☐ Damage by Electrical Facilit		☐ Aldyl A (Tan or Gray)			
☐ Encapsulation	☐ Damage by Heavy Rains/FI	ood Lightning	☐ PE2406 (Yellow or Orange)			
Fitting	☐ Damage by Earth Movemen		☐ PE2406/2708 (Yellow)			
☐ Fusion Joint ☐ Girth Weld	☐ Damage by 3 <sup>rd</sup> Party ☐ External Corrosion	☐ Unknown ☐ Other	☐ PE 3408 (Black) ☐ PE 4710 (Black)			
☐ Longitudinal Weld	☐ Internal Corrosion	LINE USE:	Other Plastic			
☐ Mechanical Joint	☐ Stress Corrosion Cracking	☐ Distribution Main	☐ Other			
☐ Plastic Tee Cap	☐ Material Failure	☐ Gathering				
☐ Other Welds ☐ Regulator	<ul> <li>☐ Plastic Crack Failure</li> <li>☐ Plastic Embrittlement</li> </ul>	☐ Single Service ☐ Branch Service				
Riser	☐ Vandalism	☐ Transmission				
Tap Connection	☐ Structure Fire	B., B.,				
Line Size Line Above Ground Yes		2-10-10 3-10-10 3-10-10 10-10-10 10-10-10-10-10-10-10-10-10-10-10-10-10-1	nserted ☐ Yes ☐ No			
High Consequence Area ☐ Yes ☐ No (Transmission Only)  Incident Report #:  EFV Installed ☐ Yes ☐ No  Material Problem Report #:						

Page 1 of 3

Material Redacted GTR0042129

-	RI	EPAIR DATA				
Repair Location						
☐ Yes ☐ No Pipeline Eng		air Remarks				
Repaired By:	Repair Date	Repair Time Pipe-to Soil (mV) (External Corrosion Only)				
REPAIR CODE:	☐ Mechanical Repair Fitting	☐ Replace Valve > or = 2-inch ☐ Fill Weld ☐ Clockspring				
☐ Bell Joint Seal	Replace Dist Main < 100 ft.	□ Replace Plastic Tee Cap □ Patch Weld □ Aquawrap				
☐ Bell Joint Clamp	Replace Dist Main > or = 100 ft	☐ Tighten Cap/Bolt ☐ Direct Deposition Weld ☐ Other ☐				
☐ Cl Repair Sleeve ☐ BJ Permabond	Deactivated Entire Service	☐ Aldyl Electrofusion Overcap ☐ Welded Sleeve/Can				
☐ Deactivate TP Main	<ul> <li>□ Deactivated Partial Service</li> <li>□ Replace Entire Service</li> </ul>	☐ Skinner Clamp ☐ Welded Save-A-Valve ☐ SS Clamp w/Anode ☐ Type A Sleeve				
☐ Replace TP Main	☐ Replace Partial Service					
Deactivate Dist Main (1 foot or more)	☐ Replace Valve < 2-inch	□ Soap and/or Tape				
SIZE INSTALLED:	REPLACED WIT	TH: ☐ STEEL ☐ PE2406/2708 (Yellow) ☐ Copper Entirely Replaced				
Field Reviewed By:	Date -	Post Repair  Yes Date  -				
Mapping Reviewed By:		Date				
	——— GENERAL I	NSPECTION DATA				
	Inspected by LAN ID:	Line Use: ☐ Distribution Main ☐ Gathering ☐ Single Service ☐ Branch Service ☐ Transmission				
LINE MATERIAL SOIL TY		SURFACE OVER PIPE FEET EXPOSED				
☐ Steel/Wrought Iron ☐ Clay	SOIL RESIST (ohm-cm	COVER ON PIPE (Inches)				
Cast/Ductile Iron Rock	☐ 0 - 1,000	□ Asphalt INTERNAL LINER □ Yes □ No				
☐ Copper ☐ Sand ☐ Aldyl-A (Tan or Gray) ☐ Loam	☐ 1,000 - 2,000 ☐ 2,000 - 5,000	☐ Soil (Previously Unsurfaced) ☐ Exposed  PAVED WALL TO WALL ☐ Yes ☐ No  NEAR PUBLIC ASSEMBLY ☐ Yes ☐ No				
☐ PE 2406 (Yellow or ☐ Wet	5,000 - 10,000	Exposed NEART OBLIC ACCEMBET 1 165 1 NO				
Orange)						
	sed Facility	Other				
☐ PE 3408 (Black)						
☐ PE 4710 (Black) ☐ Other		Line Size   Line S				
		PIPE CONDITION				
COATING TYPE Bare/None	☐ Paint ☐ Single Wrap ☐ Soma ☐ Tape ☐ Double Wrap ☐ Plast	astic				
CIRCUMFERENTIAL WELD	☐ Acceptable ☐ Cracked ☐ High/Low Ob	4 (15) (14) (15)				
the account of a visit of the account of	Dimensions not in tolerance (See Numb					
LONG SEAM		iral □ SSAW □ SMLS □ LAP □ Flash <b>NAL INSPECTION</b>				
RUST None Light	Heavy WALL THICKNESS (Req. for TP	- 504 174-5 19730107 NO 8. HOLLOW CO. C.				
	Heavy MAX. PIT DEPTH (Req. for TP) (i					
	Heavy MAX. GOUGE DEPTH (Req. for					
	INTERI	NAL INSPECTION				
	☐ Heavy					
PITTING None Light Heavy MAX. PIT DEPTH (Req. for TP) (inches)						
PRINTLINE VISIBLE  Yes  No	———— PLASTIC F	PIPE CONDITION				
PIPE MANUFACTURER (LOCATED OF	N PIPE)	MANUFACTURE DATE // (MM/DD/YY) LOCATING WIRE ☐ Good ☐ Bad ☐ None				
COLIGING Yes LINDER S	TRESS/BENT Yes DISCOLODING	C TO CRAY Yes CRACKING Yes IN CONTACT WITH Yes				
□ No	AL BEAD APPEARANCE (SEE NUMBERE	□ No □ No HARD OBJECTS □ No				
□ <10% □ 10-50% □ >50%	AC BEAD APPEARANCE (SEE NOWBERE   DIACCEP					
		ERLY INCIDENT DATA				
Damaging Party	Address	City				
Damaging Party Working For Po	G&E ☐ Yes ☐ No	Zip Code				
Phone ( ) -		·				
# INJURED:	DAMAGE # Cust.	# Cust. FIRE Yes No EXPLOSION Yes No				
# FATAL: EMPLOYEES OTHERS OTHERS	\$Interrupted   State	H Hours TNC Test No Extremely Test No Extremely Test No Media Type □ TV □ Radio □ Newspaper Name/Channel:				
<del></del>	<del></del>	res ☐ No Media Type ☐ TV ☐ Radio ☐ Newspaper NamerChamer / Damage) ☐ Yes ☐ No CPUC REPORTABLE (Major News Media) ☐ Yes ☐ No				
( *************************************		,				

Page 2 of 3

Material Redacted GTR0042130

LOCATION SKETCH							
REQUIRED for new or returned to service segments of main and/or service:  On-Site Test Per-Test  TEST in accordance with A-34	or returned to service segments of in and/or service: e Test		WELDED BY: Date:  WELDING INSPECTED PER PG&E NUMBERED DOCUMENT D-40				
BY DATE TEST QUALIFIES PIPE FOR PSIG MAOP	TYPE OF PLASTIC MATERIAL INSTALLED Manufacturer Name (Polypipe, US Poly, Performance, or KWH)	MFG. DATE (MM/DD/YY)	Date: INSPECTOR				
COMMENTS:		<u>A-93</u>					
A sketch is required for all repairs (or o	directions as to where to find the s	sketch is red	quired, if it is located on another record).				
(22.0			,				

Page 3 of 3

Material Redacted GTR0042131