Leak Grading and Response

Summary

This utility procedure documents how to grade leaks on Pacific Gas and Electric Company (Company) transmission and distribution (T&D) gas facilities. It also describes the grades of gas leaks, criteria for assigning each grade, required actions for each leak grade, and criteria for downgrading a gas leak.

Level of Use: Reference

Target Audience

- Gas maintenance and construction (M&C) personnel
- Gas mapping personnel

Safety

Perform all gas leak survey and facility-related maintenance and operations work safely and in accordance with applicable safety rules, the <u>Code of Safe Practices</u>, and <u>Utility Standard Practice (USP) 22, "Safety and Health Program."</u>

Hazards impacting this work include but are not limited to the following conditions:

- · Dangerous animals
- · Tripping and slipping
- Traffic conditions
- Vegetation, including poison oak
- Environmental surroundings
- Construction sites

Utility Procedure: TD-4110P-09

Publication Date: 08/25/2010 Rev: 0

Leak Grading and Response

Before You Start

Employees implementing this procedure must wear the following personal protective (PPE) equipment:

- Hard hat
- Traffic vest
- Proper work footwear (no sneakers allowed)
- Long-sleeved shirt
- Long pants
- Gloves (must be available)
- Safety glasses (must be available)

The following tools and materials are required to perform the procedures in this document:

- Leak survey instruments
- Impact bar
- 14-inch adjustable wrench
- Two pipe wrenches (12-inch and 18-inch)
- Curb valve wrenches as applicable
- EZ Tech cellular phone
- Soap solution in a bottle or can
- Others as applicable

Any person performing leak grading must be qualified for one of the following operator qualification subtasks:

- Operator Qualification Subtask 09-01, "Conduct Survey"
- Operator Qualification Subtask 09-02, "Leak Investigation"

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 2 of 16



Leak Grading and Response

Table of Contents - Leak Grading Procedures

Section	IIIe	Page
1	General Information	4
2	Leak Grading	4
3	Upgrading Gas Leaks	5
4	Downgrading and Clearing Gas Leaks	5
5	Grade 1 Gas Leaks	5
6	Grade 2+ (Priority Grade 2) Gas Leaks	7
7	Grade 2 Gas Leaks	9
8	Grade 3 Gas Leaks	10
9	Grade 0 Gas Leaks	11
10	Identifying and Grading Leaks on Copper Services	11
11	Grading Leaks Identified by Vegetation Leak Survey	12
12	Grading Leaks with Gas Migration	12



Leak Grading and Response

Leak Grading Procedures

1 General Information

- 1.1 Grade all gas leaks according to the instructions in this procedure.
- 1.2 Grade all gas leaks with an approved method or instrument.
- 1.3 Unless otherwise specified, all readings in this procedure refer to percent gas-in-air, subsurface readings.
- 1.4 This procedure does not apply to a non-hazardous release of gas at or downstream of the aboveground inlet gas service valve recorded in Customer Care & Billing (CC&B) processes. See Figure 1 below.




Figure 1

NOTE

The <u>Leak Survey</u>, <u>Repair</u>, <u>Inspection</u>, <u>and Gas Quarterly Incident Report – Form "A" (62-4060)</u> is required for all Grade 1 leaks below the service valve.

2 Leak Grading

A leak grade is based upon the severity and location of the leak, the danger the leak presents to persons or property, and the likelihood that the leak will become more serious within a specified amount of time. See the attached <u>Job Aid TD-4110P-09-JA-01</u>, "Gas Leak Grades."

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 4 of 16

Leak Grading and Response

Table 1 below summarizes the gas leak grades.

Table 1. Gas Leak Grades

Grade	Definition
1	Also referred to as a "hazardous leak." A gas leak that represents an existing or probable hazard to persons or property and requires immediate repair or continuous action until conditions are no longer hazardous.
2+	A gas leak that is non-hazardous to life or property at the time of detection but requires a scheduled priority repair completed within 90 days.
2	A gas leak that is non-hazardous to life or property at the time of detection but requires periodic surveillance and a scheduled repair because it presents a probable future hazard.
3	A gas leak that is non-hazardous at the time of detection and can reasonably be expected to remain non-hazardous.
0	No gas leakage is found after investigating a previous reading.

3 Upgrading Gas Leaks

IF a graded gas leak worsens,

THEN upgrade it appropriately.

4 Downgrading and Clearing Gas Leaks

The following criteria apply when downgrading all leaks:

- Use an approved method to recheck and/or subsequently downgrade a leak to Grade 0.
- Consider the soil type (sand, clay, rock, etc.), soil moisture level, and weather while
 rechecking a leak. Evaluate a Grade 2+ or Grade 2 leak in clay soil (initially graded during
 a dry season) during wet seasons carefully before downgrading or clearing a leak.
- IF the original leak grade does not meet the leak grading criteria,
 THEN issue and document the proper leak grade.
- Never downgrade a leak to Grade 3 more than once.

5 Grade 1 Gas Leaks

A Grade 1 gas leak, also referred to as a "hazardous leak," represents an existing or probable hazard to persons or property and requires immediate repair or continuous action until conditions are no longer hazardous.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 5 of 16

Leak Grading and Response

5.1 Grade 1 Leak Criteria

When one or more of the following conditions exist, grade the leak Grade 1:

- Any reading of 4.0% gas-in-air or greater on subsurface gas facilities where gas would likely migrate to within 5 feet (ft) of the outside wall of a building.
- Any gas reading on subsurface facilities in, at, or under a building; within 5 ft of a building; or in a tunnel.
- Gas can be seen, heard, or felt on any aboveground or subsurface gas facility where the presence of gas endangers persons or property.
- Escaping gas is ignited.
- Soap solution applied to an aboveground facility is blown off the facility, providing no opportunity for bubbles to form and "hold." See the attached <u>Training Video</u> <u>TD-4110P-09-VID-01</u>, "Above Ground Leak Grading Using a Soap Test."
- A leak does not meet the above criteria, yet still poses an immediate hazard in the judgment of the following personnel:
 - o The leak surveyor and/or leak survey supervisor, or
 - A leak repair employee and/or leak repair supervisor.

5.2 Actions to Take for Grade 1 Leaks

Take immediate and continuous corrective action until the conditions are no longer hazardous. Such action may include but is not limited to one or more of the following tasks:

- 1. Evacuate the premises and restrict public access to the area.
- 2. Ventilate the area by removing manhole covers, bar-holing, installing vent holes, or by other means appropriate to the situation.

NOTE

After ventilation, if there are no subsurface gas reads within 5 ft of the structure, the leak may qualify for a Grade 1 downgrade.

- 3. Eliminate hazard sources:
 - Eliminate sources of ignition.
 - If gas is burning, prevent the spread of fire, but do not necessarily extinguish the burning gas.
 - Eliminate the source of gas.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 6 of 16

Leak Grading and Response

- 4. Implement the local gas emergency plan as required.
- 5. Make continuous repair efforts until the leak is repaired or conditions are mitigated enough to downgrade the leak.
- 6. If the leak meets the criteria for a reportable incident or a safety-related condition (per <u>Utility Standard TD-4413S</u>, "Gas Event Reporting Requirements"), complete the necessary reports.

5.3 Downgrading Grade 1 Leaks

When the Grade 1 status no longer applies to a gas leak, downgrade it appropriately, as defined in this section. Note the reasoning behind the downgrade on the leak record. The repair period required for a downgraded Grade 1 leak must be consistent with that of the newly assigned leak grade.

1. Grade 1 to Grade 2+

Downgrade to a Grade 2+ leak if the leak is non-hazardous to life or property at the time of evaluation, but still requires a scheduled priority repair within 90 days of detection because it presents a possible future hazard within 6 months.

2. Grade 1 to Grade 2

Downgrade to a Grade 2 leak if the leak is non-hazardous to life or property at the time of evaluation, but still requires a scheduled repair because it presents a possible future hazard. A Grade 2 leak must be repaired within 18 months.

3. Grade 1 to Grade 3

Do not downgrade a Grade 1 leak to Grade 3.

4. Grade 1 to Grade 0

Do not downgrade a Grade 1 leak to Grade 0.

IF the leak indication is not a valid leak on Company facilities,

THEN **do not** enter the leak into the Integrated Gas Information System (IGIS). Remove the leak from IGIS if it has been entered.

6 Grade 2+ (Priority Grade 2) Gas Leaks

A Grade 2+ leak is non-hazardous to persons or property at the time of detection, but still requires a scheduled priority repair within 90 days or less.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 7 of 16

Leak Grading and Response

Grade 2+ Leak Criteria

When one or more of the following conditions exist, grade the leak Grade 2+ as follows:

- Any leak previously graded Grade 1, based on leak readings and the location of the leak, where the immediate hazard has been eliminated through crew action other than a leak repair (for example, by ventilating the leak), but where the leak still requires priority repair.
- Any leak that is damaging trees, crops, or ornamental plants, excluding lawns.
- Any leak that causes a public nuisance, anxiety, or apprehension.
- Soap solution on an aboveground facility that can hold a cluster of bubbles under special circumstances (e.g., when the meter set is in a cabinet).
- A leak does not meet the above criteria, yet still poses a Grade 2+ hazard in the judgment of any of the following personnel:
 - The leak surveyor and/or leak survey supervisor, or
 - A leak repair employee and/or leak repair supervisor.
- 6.1 Actions to Take for Grade 2+ Leaks

Take the following actions for a Grade 2+ leak:

- 1. When grading a leak Grade 2+, establish the repair period, not to exceed 90 days from the date reported, to the date.
- 2. Repair or clear the leak, as designated by the operating department, in a time period not to exceed 90 days, to the date, from the date reported or before the ground freezes or other adverse changes in venting conditions occur.
- 6.2 Downgrading Grade 2+ Leaks

When the Grade 2+ status no longer applies to a leak, downgrade it to the appropriate grade as defined in this section. Note the reasoning behind the downgrade on the leak record.

1. Grade 2+ to Grade 2

Downgrade to Grade 2 if the leak's status changes to meet Grade 2 criteria.

2. Grade 2+ to Grade 3

Downgrade to Grade 3 if the leak's status changes to meet Grade 3 criteria.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 8 of 16

Leak Grading and Response

3. Grade 2+ to Grade 0

IF the leak indication is not a valid Grade 2+ leak or if no leak is found,

THEN perform the following tasks:

- Grade it Grade 0.
- Note the action taken or the reasoning behind the downgrade on the leak record.
- Consider the conditions to determine if a recheck is necessary.

7 Grade 2 Gas Leaks

A Grade 2 leak is non-hazardous to persons or property at the time of detection but still requires a scheduled repair because it presents a probable future hazard. Grade 2 leaks must be repaired within 18 months.

7.1 Grade 2 Leak Criteria

When one or more of the following conditions exist, grade a leak Grade 2:

- Any reading of 4% gas-in-air or greater in a well-ventilated Class 3 or 4 location, such as a pipeline right-of-way, station yard, or a non-wall-to-wall paved area, where the leak does not otherwise qualify as Grade 1 or 2+.
- Any reading of 2% gas-in-air or greater in a wall-to-wall paved area where the leak does not otherwise qualify as Grade 1 or 2+.
- Any reading between 2% gas-in-air and 4% gas-in-air in a substructure where gas would likely migrate and create a probable future hazard.
- Any reading between 2% gas-in-air and 4% gas-in-air in a confined space.
- Soap solution on an aboveground facility that can hold a cluster of bubbles.
- A leak does not meet the above criteria, yet still poses a Grade 2 hazard in the judgment of the following personnel:
 - o The leak surveyor and/or leak survey supervisor, or
 - o A leak repair employee and/or leak repair supervisor.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 9 of 16

Leak Grading and Response

7.2 Actions to Take for Grade 2 Leaks

Take the following actions for a Grade 2 leak:

- 1. Repair or clear the leak no later than 18 months, to the date, from the date reported or before the ground freezes or other adverse changes in venting conditions occur.
- 2. Repair or clear all leaks on mains under street pavement and associated service lines before known street overlay work or known street reconstruction begins.
- 3. Recheck Grade 2 leaks before repair at intervals of 6 months, not to exceed the last day of the 7th month, to the date.

7.3 Downgrading Grade 2 Leaks

When Grade 2 status no longer applies to a leak, downgrade the leak to the appropriate classification as defined in this section. Note the reasoning behind the downgrade on the leak record.

1. Grade 2 to Grade 3

Downgrade the leak to Grade 3 if it is non-hazardous and can reasonably be expected to remain non-hazardous.

2. Grade 2 to Grade 0

IF the leak indication is not a valid Grade 2 leak or if no leak is found,

THEN perform the following tasks:

- Grade it Grade 0.
- Note the action taken or the reasoning behind the downgrade on the leak record.
- Consider the conditions to determine if a recheck is necessary.

8 Grade 3 Gas Leaks

A Grade 3 leak is non-hazardous at the time of detection and can reasonably be expected to remain non-hazardous.

8.1 Grade 3 Leak Criteria

When one or more of the following conditions exist, grade the leak Grade 3:

Any reading less than 4% gas-in-air in a well-ventilated Class 3 or 4 location, such
as a pipeline right-of-way, station yard, or non-wall-to-wall paved area, where the
leak does not otherwise qualify as Grade 1, Grade 2+, or Grade 2.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 10 of 16

Leak Grading and Response

- Any reading less than 2% gas-in-air in a wall-to-wall paved area, where the leak does not otherwise qualify as a Grade 1, Grade 2+, or Grade 2.
- Soap solution on an aboveground facility that foams small bubbles.
- Any other leak that is non-hazardous, can reasonably be expected to remain non-hazardous, and has not previously been downgraded to Grade 3.

8.2 Action to Take for Grade 3 Leaks

Recheck Grade 3 leaks during the next scheduled survey.

8.3 Downgrading Grade 3 Leaks

IF the leak indication is not a valid Grade 3 leak or if no leak is found,

THEN perform the following tasks:

- Grade it Grade 0.
- Note the action taken or the reasoning behind the downgrade on the leak record.
- Consider the conditions to determine if a recheck is necessary.

9 Grade 0 Gas Leaks

IF a leak indication is not a valid leak or no leak is found,

THEN grade it Grade 0.

10 Identifying and Grading Leaks on Copper Services

Always grade any leak suspected to be on a copper service as Grade 1, Grade 2+, or Grade 2, but never as Grade 3 or Grade 0.

If a leak initially suspected of being on a copper service is not on a copper service, re-evaluate its designation as suspected copper via the following process:

- 10.1 Gas M&C personnel submit a request to the process owner proposing that the suspected copper designation be removed from the leak.
- 10.2 After critical review, the process owner authorizes and requests the change through IGIS administrators.
- 10.3 If the change is made in IGIS, local Company employees update and initial all relevant local leak records with the new leak data.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 11 of 16

Leak Grading and Response

11 Grading Leaks Identified by Vegetation Leak Survey

Where vegetation surveys are permitted, verify a gas leak identified by a vegetation leak survey using an approved combustible gas indicator (CGI) and in accordance with Utility Procedure
TD-4110P-12 "Subsurface Leak Investigation." Then, grade the leak according to this procedure.

12 Grading Leaks with Gas Migration

IF different readings are found in multiple locations and the readings and conditions indicate that there is actually only one leak with gas migration,

THEN assign only one leak number and report the most severe conditions.

END of Instructions

Definitions

Blowing gas: A gas leak which can be heard, seen, or felt, in accordance with the following definitions:

- **Heard:** A gas leak that makes a "blowing or hissing" sound.
- Seen: A gas leak that does not hold foam or soap solution or a leak that blows visible dust or dirt into the air. Bubbles coming through water may be included.
- Felt: A gas leak that is detectable by touch.

Building: Any structure normally or occasionally entered by humans for business, residential, or other purposes in which gas can accumulate. The one exception is Company-owned structures whose sole purpose is to protect pipeline facilities from the environment (such as meter houses and regulator station houses).

CGI: This acronym has the following two definitions, easily distinguished by the context in which they are used:

- Can't Get In: A location where there is presently no access to perform maintenance work.
- Combustible gas indicator: A type of leak survey instrument capable
 of detecting and measuring gas concentrations (of transported gas) in
 the atmosphere.

Gas facilities: All Company-operated gas lines and related appurtenances.

Aboveground: All exposed gas piping, fittings, and assemblies, including aboveground meter set assemblies.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 12 of 16

Leak Grading and Response

Subsurface: All gas piping, fittings, and assemblies below ground level.

IGIS: Integrated Gas Information System. The electronic system of record for gas leaks and other gas system information.

Leak: The unintentional escape of gas from containment.

Leak grade: The classification of a leak based on leak readings, public exposure, and location.

Leak recheck: Any leak survey performed with an approved instrument in the area of an existing Grade 2+, Grade 2, or Grade 3 leak.

Leak repair: An action to restore a gas facility to sound condition by eliminating a gas leak.

Leak survey: A patrol for gas leakage in any area where Company gas facilities exist or where a gas leak is reported or suspected.

Operator qualified: Employees evaluated and qualified in accordance with Utility Standard S4450, "Operator Qualification Program."

Process owner: The engineering employee responsible for managing the leak survey process.

Substructure: Any structure, tunnel, passageway, or other confined space below ground level where gas could accumulate.

Tunnel: A subsurface passageway into which a person could enter and gas could accumulate. For purposes of this procedure, "tunnel" also includes large sewers, storm drains, pipelines, and conduits.

Venting: Drilling a hole or holes or excavating above and/or around a leak to allow gas to dissipate or vent.

Wall-to-wall: An area is considered to have wall-to-wall pavement when either of the following conditions exists:

- There are buildings on both sides of the street with essentially uninterrupted pavement from the building walls on one side of the street to the building walls on the other side of the street.
- A gas main is under continuous pavement from its position to the nearest buildings and the distance from the gas main to the buildings is less than the distance to any other areas that allow significant venting.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 13 of 16

Leak Grading and Response

Implementation Responsibilities

Gas M&C personnel are expected to perform leak survey and response measures in accordance with this procedure.

Gas mapping personnel are expected to provide documentation in support of this procedure.

Gas superintendents are expected to provide resources to perform the work described in this procedure.

Governing Document

<u>Utility Standard S4110, "Leak Survey and Repair of Gas Transmission and Distribution Facilities"</u>

Compliance Requirement/ Regulatory Commitment

Code of Federal Regulations (CFR), Title 49, "Transportation," Section 192.703(c)

Reference Documents

Code of Safe Practices

Division Gas Emergency Plans

Gas Numbered Documents:

- M-53, "Portable Combustible Gas Indicator Specification"
- M-53.1, "Portable Combustible Gas Indicator Operations and Maintenance Instructions"
- M-53.2, "Portable Hydrogen Flame Ionization Gas Detector"
- M-53.3, "Verifying the Calibration of Portable Combustible Gas Indicators, Hydrogen Flame Ionization Units, and OMDS"
- M-53.4, "Mobile Leak Survey Hydrogen Flame Ionization"
- M-53.5, "Mobile Leak Survey Optical Methane Detection"

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 14 of 16

Leak Grading and Response

- M-53.6, "Remote Methane Leak Detector"
- M-53.7 "Remote Methane Leak Detector Operating Procedures"
- M-54.1, "Impact Bar Probe"
- O-16, "Corrosion Control of Gas Facilities"

Gas Piping Technology Committee (GPTC) Guide for Gas Transmission and Distribution Piping Systems, Material Appendix G-192-11, "Gas Leakage Control Guidelines for Natural Gas Systems" – Available through DOT Gas Regulations at http://www/TechLib/default.asp?body=all_go_regs.htm

<u>Leak Survey, Repair, Inspection, and Gas Quarterly Incident Report – Form "A" (62-4060)</u>

Operator Qualification Subtasks:

- 09-01, "Conduct Survey"
- 09-02, "Leak Investigation"

Utility Procedure TD-4110P-12 "Subsurface Leak Investigation"

Utility Standards:

- TD-4413S, "Gas Event Reporting Requirements"
- S4450, "Operator Qualification Program"
- S6434, "Gas Leak and Odor Response"

Utility Standard Practice (USP) 22, "Safety and Health Program"

Appendices

NA

Attachments

- Job Aid TD-4110P-09-JA-01, "Gas Leak Grades"
- <u>Training Video TD-4110P-09-VID-01</u>, "Above Ground Leak Grading Using a Soap Test"

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 15 of 16



Leak Grading and Response

Document Recision

This utility procedure cancels and supersedes the following gas information bulletins:

- 245 Rev. 1, "Change in Grade 1 Gas Leak Grading Criteria," dated 03/01/09.
- TD-4110B-001, "Soap Solution Testing for Gas Leaks," dated 05/21/10.

Approved By

Robert P. Fassett Director

Document Owner



Document Contact



Revision Notes

Where?	What Changed?
NA	This is the initial issue of this document.

PG&E Internal Information, SL2

©2010 Pacific Gas and Electric Company. All rights reserved.

Page 16 of 16