

Self-Contained Relief Valve Maintenance Record

GT&D Rev. 1/1/2010 TD-4430P-02-F06

Make all entries in black or blue permanent ink.

Station				System:			
Freque	ency: A	\nnual	Anniver	sary Month	PID	·	3lk
Make Conn. Inlet Outlet Other Information							
Make			Тур		Outlet	Other Informati	on
Model # Serial #						+	
•							
Maximum Permissible Downstream Pressure (Lesser of MAOP+10% or pressure to produce 75% SMYS. See Cap Calcs.)							
Annual Capacity Review Required (See Attached) Note: Do not use this form for packaged relief valve. Use package relief form.							
Maximum (Relief) Set Pressure:							
Date .	Technician Initials/LAN ID	As Found	As Left		Condition		Supervisor Approval LAN ID/Date
	7						7
	7						7
	f.						T .
	1						1
	/						/
	1						1
	/						1
	i i						<i>I I</i>
	7						7
	:						
	;						7
	7						7
	1						T.
	1						7
	7						7
	T.						I
	1						7
	į.						I .
	/						/
	1						/
	/						1
	<i>[]</i>						<i>l l</i>
	; /						7
	1						/
	7						7
	7						7
	;			<u> </u>			,



Self-Contained Relief Valve Maintenance Record

CT&D Rev. 1/1/2010 TD-4430P-02-F06

Relief Valve Records Instructions

Tag: Common Valve Label (e.g., V-21, V-B, etc.) Tag should match label on the "Capacity Review

of Relief Devices" and on the actual valve in the field.

Station: Station name.

System: Describe system where the relief valve is located (e.g., main gas relief protecting Line 131, gas

rack no.1, compressor fuel gas).

Note: With the Tag and Station names and the System description, the identification and

location of the relief valve must be clear.

Bar ID: PLM bar ID.

PID: P&ID, elementary drawing, or operating diagram. If none available, enter N/A.

Blk.: The coordinates on drawing; such as, A5, B3, etc. PG&E P&ID drawings have alphanumeric

characters on the left and top sides to help locate items. If none available or not applicable,

enter N/A.

Conn.: Connections.

Type: Screwed or flanged. Note: Some reliefs do not have outlet connections; enter N/A.

Maximum Permissible Downstream Pressure (MPDP): This number should agree with the Maximum Permissible Downstream Pressure listed for item 2 "Station Pressure Conditions," Part II of Capacity Review of Relief Devices (see GS&S H-70, "Pressure Relief Devices"). Typically, the MPDP is the lower of MAOP plus 10% or pressure to produce the pipe stress of 75% SMYS.

MAOP: Use the P2 value in the "Capacity Review of Relief Devices".

Annual Capacity Review Required: Box should be checked for reliefs requiring annual capacity calculation review.

Maximum (Relief) Set Pressure: Enter value. This value is usually determined based on UO Standard 4125.2, "Establishing Setpoints on Overpressure Protection Devices." (This number should agree with the value listed in "Maximum Pressure Setting," Part II of Capacity Review of Relief Devices, under "Relief Device(s) Protecting Lines of System Described Above.")

Note: This set pressure has been established to ensure that the relief valve will reach its required capacity before the system exceeds the maximum permissible downstream pressure.

As Found (Setting): The initial "As Found" condition should be observed and recorded in this box. Once the relief valve is exercised, the pressure that trips the relief valve will probably change from the initial As Found pressure.

Note: The "As Found" setting must be below the Maximum Permissible Downstream Pressure. If actual As Found is higher, this indicates that either the relief valve needs to be overhauled or the relief valve is inappropriate for the condition of service. Options to resolve the problem include rebuilding the relief valve, replacing the relief valve, or lowering the relief setting (may cause operational problem). Contact appropriate pipeline or facilities engineer.

As Left (Setting): The actual "As Left" setting may be set less than Normal Relief Set Pressure but never more than this value.