

75-374
4/29/75

**PACIFIC GAS AND ELECTRIC COMPANY
GAS HOLDER INSPECTION - HIGH PRESSURE**

Location 615 7th AVE SANTA CRUZ
Holder No 423-13-1P (G) Size 3mmCF Month APRIL Year 1983

(OPERATOR'S NOTE When space provided below is not ample use reverse side of this form)

	Condition In Which Found	Condition In Which Left
: Monthly		
1 Holder pressure - by recording gage	618	618
2. Check of holder pressure - by test gage	618	618
3. Check all valves for freedom of operation	✓	✓
4. Check all lubricated valves for lubricant	✓	✓
5. Is relief device shutoff valve (if any) locked open?	N/A	
6. Inspect relief devices for leaks	✓	
7. Inspect regulators for proper operation	✓	
8. Inspect expansion rollers or joints as to freedom and lubrication	✓	
9. Inspect and operate drips	✓	
10 Hours spent on above inspection	0.60	
11 Summarize operating condition of the station, indicating any changes or improvements that are advisable		

Signed

Date

4-26-83