



Memorandum

Date May 2, 1994 **File #**
To VARIOUS
From DIRECTOR, SYSTEM OPERATIONS & SCHEDULING
Subject Scada Alarm Policy



Please review with each of the Transmission Coordinators, Gas Control Operators and Gas Supply Coordinators the following System Operations and Scheduling SCADA alarm policy

When a Hi-Hi or Lo-Lo gas quality pressure or flow alarm limit is breached, immediate notification must be made to the appropriate parties

Hi-Hi and Lo-Lo alarm limits are not to be changed unless directed by the Transmission Supervisor and Operation Supervisors. Hi and Lo alarm limits will continue to be set at the discretion of the Transmission Coordinators, Gas Control Operators, and Gas Supply Coordinators

Gas transmission system Hi-Hi and Lo-Lo alarm limits are being reviewed in System Operations and Scheduling. Upon completion of the review, the alarm limits will be forwarded to the appropriate Load Center or Terminal for inclusion in your SCADA system

The Load Centers and Terminals Operation Supervisors will continue the yearly practice of contacting the appropriate Gas Operation or Division personnel regarding Hi-Hi and Lo-Lo alarm limits for Distribution Feeder Mains, and high and low pressure distribution systems. The Gas Control Operators and Gas Supply Coordinators will make changes to these alarm limits as directed by the Operation Supervisors

Any question regarding this policy, please contact me at extension



cc Bill Mazotti
Hal LaFlash

