

**List of Station Batteries and Testing Intervals**

<b>Location</b>	<b>Designation</b>	<b>Manu- facturer</b>	<b>Model</b>	<b>Installed</b>	<b>Volts</b>	<b>Test Interval</b>	<b>Last Test</b>
Antioch	46 V Telecom	GNB	85A17	5/1/1992	46	Annual	5/9/2003
Antioch	UPS Battery	Deka	6AVR75-13	3/22/2002	125	Annual	9/8/2004
Bethany	46 V Telecom	Deka	6AVR75-9	2/18/2005	46	Annual	
Bethany	UPS Battery	Yuasa	DD40-17	5/20/1999	125	Annual	6/21/2004
Brannan Island	Station 125 V Battery	Alcad	SD17	9/7/2001	125	5 Year	1/24/2002
Brentwood	48 V Telecom	Deka	AVR75-11	12/15/2003	48	Annual	3/10/2004
Brentwood	UPS Battery	Deka	6AVR75-05FR	12/1/2003	480	Annual (1)	2/19/2004
Burney	Station Battery	C&D	KCR-11	9/29/1990	125	5 Year	7/27/2004
Chico	125 V Telecom	C&D	HD-350	1/1/2003	125	On Request	2/13/2003
Delevan	Station Battery	C&D	KC-11	9/7/1986	125	2 Year	10/14/2003
Gerber	24 V Battery	Deka	6AVR-85-9	3/1/2002	24	Annual	9/14/2004
Gerber	48 V Telecom	C&D	LS6-200	10/17/2001	48	Annual	9/15/2004
Gerber	UPS Battery	Deka	6AVR-85-9	10/18/2002	125	Annual	4/20/2005
Hermann	Station Battery	GNB	50A05	7/1/2000	24	3 Year	1/15/2002
Hershey Jct	Station 125 V	Power	12120X	4/12/2001	125	Annual	4/18/2005
Hinkley	24 V Battery	GNB	90A17	12/15/1999	24	Annual	9/2/2004
Hinkley	46 V Telecomm	C&D	HD400	12/1/1999	46	Annual	2/1/2005
Hinkley	UPS Battery	GNB	90A09	12/1/1999	125	Annual	9/2/2004
HPPP	Unit #1 Station	C&D	3DCU-9		125	On Request	
HPPP	Unit #2, #3 Station	Exide	FTA23		125	On Request	3/12/2001
HPPP	Unit #2, #3 UPS	Power	PRC1265		125	On Request	3/8/2001
HPPP	Unit #4 Station	Gould	NCX-15		125	On Request	3/7/2001
HPPP	Unit #4 UPS	C&D	HD500		125	On Request	3/6/2001
Irvington	UPS Battery	Deka	6AVR45-9	10/19/2001	125	Annual	2/24/2005
Kettleman	New Station Battery	C&D	LCR-23	12/15/2000	24	5 Year	4/23/2001
Los Medanos	48 V Telecom	C&D	LS6-200	9/29/2001	48	Annual	6/22/2004
Los Medanos	UPS Battery	C&D	HD400	9/1/2000	125	Annual	6/22/2004
McDonald Compressor Station	48 V Telecom	C&D	LS-12-100	1/1/1998	48	Annual	2/14/2005
McDonald Compressor Station	UPS Battery 1	Dynasty	UPS 12-370	6/1/2003	240	Annual	2/14/2005
McDonald Compressor Station	UPS Battery 2	Dynasty	UPS 12-370	6/1/2003	240	Annual	2/15/2005
Milpitas	48 V Telecom	GNB	MCT-5	11/1/2001	48	5 Year	11/28/2001
Milpitas	UPS Battery	Alcad	SD-7	10/12/2001	125	5 Year	12/19/2001

Location	Designation	Manu- facturer	Model	Installed	Volts	Test Interval	Last Test
Santa Rosa	24 V Station Battery	C&D	DCU-13	9/1/2000	24	5 Year	2/15/2001
Tionesta	28 V Station Battery	C&D	LCR-13	11/9/1990	28	5 Year	4/19/2005
Tionesta	48 V Telecom	C&D	HDL-260	7/10/2001	48	5 Year	10/2/2002
Topock	24 V Emergency Lighting	Deka	AVR85-23	10/15/2001	24	Annual	9/1/2004
Topock	24 V Station Battery	GNB	90A23	12/1/1999	24	Annual	9/1/2004
Topock	46 V Telecom	C&D	HD400	4/29/2003	46	Annual	9/1/2004
Topock	UPS Battery	Deka	6AVR85-9	11/1/2001	125	Annual	8/31/2004
Turner Cut	48 V Telecom	GNB	MCT-5	11/1/2001	48	5 Year	11/10/2001
Turner Cut	Generator 1 Starting Battery	Hoppecke	FNC-311H	5/20/2002	32	5 Year	5/26/2004
Turner Cut	Generator 2 Starting Battery	Hoppecke	FNC-311H	5/20/2002	32	5 Year	5/27/2004
Turner Cut	Station Battery	Deka	AVR85-17	5/23/2002	125	Annual	5/27/2004
Walnut Creek	48 V Telecom	GNB	75A13	1/1/1991	48	Annual	7/21/2004
Whiskey Slough	48 V Telecom	Deka	AVR85-9	12/1/2001	48	Annual	8/25/2004
Whiskey Slough	Gen 1 Starting Battery	Hoppecke	FNC208H	9/12/2000	32	2 Year	8/26/2004
Whiskey Slough	Gen 2 Starting Battery	Hoppecke	FNC208H	9/12/2000	32	2 Year	8/26/2004
Whiskey Slough	UPS Battery	Deka	AVR85-17	8/21/2002	125	Annual	8/25/2004

**Notes:**

1. Brentwood UPS battery to be tested under annual renewable contract with Liebert due to the large size of the battery.