

# Monthly Odorization Report

Electronic Display Odorizers

DAY	Odorant Injected (lbs)	Accumulated Flow (MMscf)	Odorization Rate (lb/MMscf)	Comments	Completed By
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
	0	0	* 0.00		

End-of-Month Tank Volume (or %):  gallons \_\_\_\_, percentage \_\_ (check one)

Date: _____	Odor Intensity Reading: _____ % gas in air
Line: _____	Sniff Test Location: _____
Station: _____	Monthly Report Ending: _____
Tank Capacity: _____ gals	Approved by: _____

Odorant density for 50/50 (THT/TBM) blend = 7.45 lb/gal  
 Conduct odor intensity test once per month

**Send original completed forms to:**  
 GSM&TS Station  
 Engineering,  
 375 No. Wiget Ln,  
 Walnut Creek

\*A copy of the completed form must be kept in the district/division for 5 years.