Pacific Gas and Electric Company. INTERFERENCE TEST FORM							
PG&E NO.	CP SYSTEM N	O. D	IVISION		OPERATING HQ	CITY	FO-16-E
			RECT	IFIER			
LOCATION			91 252	(a) (a)			
DC RATING Amperes Volts				DC SETTING  Amperes Volts			s
,	«прелев		OIL RES	SISTIVITY			
AVERAGE SOIL RI	ESISTIVITY FOR	SHALLO	W WELL	. ANODES:	0	hm/Cm	
TOTAL SOIL RESI	S: Ohms						
		PIPE-1	TO-SOII	_ POTENT	ΓIAL		
PROTECTED STRUC	CTURE	ON			OFF		
NON-PG&E STRUCT	URE	ON			OFF		
NON-PG&E STRUCTURE		ON			OFF		
NON-PG&E STRUCTURE OWNER					TELEPHONE:		
CORRECTIVE ACTIO	ON TAKEN:						

1 of 3

Material Redacted GTR0008555

# INTERFERENCE TEST ON SHALLOW BED AND DEEP WELL ANODE INSTALLATIONS:

- 1. Ensure that the CPA is clear of contacts.
  - Use PCM or hard wire spanning.
- 2. Take interrupted pipe-to-soil potentials on the closest gas service or test station. Locate the electrode directly over the protected structure when possible.
  - Pipe-to-soil potentials should be no more than -1,600 mV on our gas structure.
- 3. Take interrupted pipe-to-soil potentials on the closest foreign underground metallic structure.
  - The ON potential should be more negative, in most cases, than the OFF potential when doing an interruption.
  - If the ON potential is more positive (less negative) than the OFF potential then a degree of interference is present on the foreign structure.
- 4. Do a coating evaluation with the PCM, mA per square foot in the area of the anode bed.
- 5. A soil resistivity test is required if one was not previously taken and recorded. If it is a deep well installation, a total circuit resistance test is required.
- 6. Make a detail drawing of the location and include all measurements of where potentials were measured on the interference form. Show all distances between metallic structures.
- 7. Refer to Corrosion Control Gas Standard 0-16, page 6 of 14, G. "Rectifier Adjustment."

# IF ANODIC INTERFERENCE IS SUSPECTED ON A FOREIGN STRUCTURE, FOLLOW THIS PROCEDURE:

- 1. Turn down the rectifier while trying to keep P/S readings above -850mV.
- 2. Water shallow bed anodes or flush deep well anode installations to lower the ground bed resistance, which will lower the voltage gradient of the anode bed.
- 3. If after turning down the rectifier and watering or flushing the anodes, CP cannot be maintained, try installing galvanic anodes at the lowest read potentials, or try to find a shallow bed location. (This step may require relocating the bimonthly read locations.)

Material Redacted GTR0008556

## "Interference Test Form" Instructions

#### **RECORD**

PG&E Number: Record the rectifier's PG&E identification number.

CP System Number: Record the cathodic protection system number for the area.

Division/Operating Headquarters/City: Record those elements for the tested rectifier.

#### **RECTIFIER**

Location: Record the exact location of the rectifier.

DC Rating: Record the manufacturer's rating for the rectifier (amperes and volts).

DC Setting: Record the maximum amperes and volts at the time of the interference

test.

#### **SOIL RESISTIVITY**

Average Soil Resistivity for Shallow Well Anodes/Total Soil Resistivity for

Deep Well Anodes: Record soil resistivity for the shallow or deep well anodes as applicable to

the test.

## PIPE-TO-SOIL POTENTIALS

Pipe-to-Soil Potentials on Protected

and Non-PG&E Structure: After setting up an interrupter, record "ON" and "OFF" P/S potentials on

the protected facility (e.g., PG&E Gas Main) and any non-PG&E

structures that could be affected by the rectifier.

Non-PG&E Structure Owner and

Telephone: Record the name of the owner of non-PG&E structure and a local

telephone number.

Drawing: Include a drawing of the rectifier, anode bed, and the location of any

non-PG&E structure.

To insert or paste a drawing:

Make the following selections on the Word menu bar,
 View => Toolbars => Forms. The Forms toolbar appears.

2. Click the padlock icon to unlock the form.

3. Paste or insert the drawing in the indicated area of the form.

Click the padlock icon to lock the form.

Corrective Action Taken: Record the corrective action taken, if any, needed to mitigate any

interference situations.

Date/Prepared by: Record the date and the name of the person who conducted the

interference test.

3 of 3

Material Redacted GTR0008557