PG&E NO.	-	ERFE	RENC	E TES	Γ FORM		GD&T 03/0 FO-16-
FG&L NO.	CP SYSTEM	NO.	DIVISION		OPERATING HQ	CITY	
			RECT	TFIER			
LOCATION							
DC RATING			DC SETTING				
	Amperes	Volts	eou be	SISTIVITY	Amperes	Volts Volts	
AVERAGE SOIL I	RESISTIVITY FO					hm/Cm	
TOTAL CIRCUIT						hms	
				_ POTENT			
PROTECTED STRU	JCTURE	ON			OFF		
NON-PG&E STRUC	TURE	ON			OFF		
NON-PG&E STRUCTURE		ON			OFF		
NON-PG&E STRUC	CTURE OWNER		*		TELEPHONE		

1 of 3

Material Redacted GTR0008630

INTERFERENCE TEST ON SHALLOW BED AND DEEP WELL ANODE INSTALLATIONS:

- 1. Ensure that the CPA is clear of contacts.
 - · Use PCM or hard wire spanning.
- 2. Take interrupted pipe-to-soil potentials on the closest gas service or test station. Locate the electrode directly over the protected structure when possible.
 - Pipe-to-soil potentials should be no more than -1,600 mV on our gas structure.
- Take interrupted pipe-to-soil potentials on the closest foreign underground metallic structure. When performing an interrupted test, set the interrupter at 4 seconds on and 1 second off to minimize depolarization.
 - The ON potential should be more negative, in most cases, than the OFF potential when doing an interruption.
 - If the **ON** potential is more positive (less negative) than the **OFF** potential then a degree of interference is present on the foreign structure.
- 4. A soil resistivity test is required if one was not previously taken and recorded. If it is a deep well installation, a total circuit resistance test is required.
- 5. Make a detail drawing of the location and include all measurements of where potentials were measured on the interference form. Show all distances between metallic structures.
- 6. Refer to Corrosion Control Gas Standard 0-16, page 6 of 14, G. "Rectifier Adjustment."

IF ANODIC INTERFERENCE IS SUSPECTED ON A FOREIGN STRUCTURE, FOLLOW THIS PROCEDURE:

- 1. Turn down the rectifier while trying to keep P/S readings above -850mV.
- 2. Water shallow bed anodes or flush deep well anode installations to lower the ground bed resistance, which will lower the voltage gradient of the anode bed.
- 3. If after turning down the rectifier and watering or flushing the anodes, CP cannot be maintained, try installing galvanic anodes at the lowest read potentials, or try to find a shallow bed location. (This step may require relocating the bimonthly read locations.)

Material Redacted GTR0008631

"Interference Test Form" Instructions

RECORD

PG&E Number: Record the rectifier's PG&E identification number.

CP System Number: Record the cathodic protection system number for the area.

Division/Operating Headquarters/City: Record those elements for the tested rectifier.

RECTIFIER

Location: Record the exact location of the rectifier.

DC Rating: Record the manufacturer's rating for the rectifier (amperes and volts).

DC Setting: Record the maximum amperes and volts at the time of the interference

test.

SOIL RESISTIVITY

Average Soil Resistivity for Shallow Well Anodes/Total Circuit Resistance

for Deep Well Anodes: Record soil resistivity for the shallow or deep well anodes as applicable to

the test.

PIPE-TO-SOIL POTENTIALS

Pipe-to-Soil Potentials on Protected

and Non-PG&E Structure: After setting up an interrupter, record "ON" and "OFF" P/S potentials on

the protected facility (e.g., PG&E Gas Main) and any non-PG&E

structures that could be affected by the rectifier.

Non-PG&E Structure Owner and

Telephone: Record the name of the owner of non-PG&E structure and a local

telephone number.

Drawing: Include a drawing of the rectifier, anode bed, and the location of any

non-PG&E structure.

To insert or paste a drawing:

Make the following selections on the Word menu bar,
 View => Toolbars => Forms. The Forms toolbar appears.

2. Click the padlock icon to unlock the form.

3. Paste or insert the drawing in the indicated area of the form.

4. Click the padlock icon to lock the form.

Corrective Action Taken: Record the corrective action taken, if any, needed to mitigate any

interference situations.

Date/Prepared by: Record the date and the name of the person who conducted the

interference test.

3 of 3

Material Redacted GTR0008632