

Survey Leak Log

Division: Peninsula
District: Peninsula
Wall Map: 3279

Survey Key 16045

Leak Number	Address/City	GR V*	Map Plat	2% CD / Date	Read Location	Date Repair	Due Date	Read	2% CD	Dwn Via Vent	I.* Ins.#	GR	Location/Remarks	Date	Initials	GR3 Rchk Interval Mos	Cont 4	
05987651	test	2	3279	100	9/22/2005	9/22/2005	9/24/2005											
1	Belmont		G01	test		06/22/2005												
05200161	920 Grand St Redwood Cy	2	3279	1	A	2/28/2005	2/28/2005											
2			G01	over SVC TEF longline			7											
00200371	o/rm intersec Madison & Fulton Ave. Redwood Cy	3	3279	3		2/9/2005	3/9/2005											
3			G01	n/w/c 6' out c @ stop sign			60											
05200121	862 Cleveland St Redwood Cy	2	3279	10		2/28/2005	2/28/2005											
4			G01	over main by fence post			7											
05200071	522 Cleveland St Redwood Cy	2	3279	4		2/23/2005	2/23/2005											
5			G01	reading over valve @ main			7											

Leak Surveyor to complete: Reading, 2% or Less code, Downgrade Via Ventilation, Instrument Type, Instrument #, Grade, Location/Remarks, Date & Time Rechecked, Initials, Grade 3 Recheck Interval and Continue 4 Months Venting Flag (V*): A "Y" will display below the previous grade if this leak is being rechecked at 4 month intervals due to a previous downgrade via ventilation.

Due Date: This is the absolute due date required by CPUC and PCE Standard Practices
Instrument Type (I*): H - Hydrogen Flame Ionization or C - combustion gas indicator

Dwn Via Vent: Enter Yes if the leak is downgraded via ventilation or No if not
Cont 4 Mos: If the leak was downgraded via ventilation at least 12 months ago, enter Yes to continue 4 month recheck intervals or No to discontinue 4 month recheck intervals.

GR3 Rchk Interval: Enter the # of months for the grade 3 leak recheck interval, if different from next scheduled survey (e.g. 12, 18, 36, 60) if left blank, default will be the next scheduled survey after the current year survey.

2% CD: Enter the 2% reason code if the grade is 1, 2+ or 2 and the reading is 2% or less. A-Wall to wall and traveling, B-Next to, at or under building, C-Color next to public gathering location, D-In foreign structure, E-Audible and/or visible, F-On facility in extremely poor condition.

G-A1 least second customer call out, H-Leak is reported as 0% Gas Visual, J-Leak within the scope of work t.; others, S-Leak is suspected to be on a copper service

****** Aform Printed for this leak. ******* Grade 3 downgrade is not allowed.

Selection Criteria Division = Peninsula, District = Peninsula, Map = 3279, Plat = G01