

Recheck Leak Log

Division: Peninsula
District: Peninsula
Wall Map: 3279

Rechecks due: By 10/1/2005

Recheck Key 16044

Leak Number	Address/City	GR Plat V*	Map Block	Read (% gas) /		Date Reptd	Due Date	2% Dwn Via Vent	GR Ins.#	Location/Remarks	Date Time	GR3 Rchk Interval Mos	Cent
				2% CD	Read Location								
05200161 1	920 Grand St Redwood Cy	2 G01 010	3279	1	A	2/28/2005	2/28/2005						
						over SVC TEE longside	7						
05200121 2	862 Cleveland St Redwood Cy	2 G01 023	3279	10		2/28/2005	2/28/2005						
						over main by fence post	7						
05200071 3	522 Cleveland St Redwood Cy	2 G01 026	3279	4		2/23/2005	2/23/2005						
						reading over valve @ main	7						
04200491 ** 4	1122 Cleveland St Redwood Cy	3 G01 V 051	3279	3		2/9/2005	4/15/2004						
						Under sidewalk near main	4						
05200141 5	1715 Madison Ave Redwood Cy	2 G01 074	3279	4		2/28/2005	2/28/2005						
						over SVC TEE @ main	7						

Leak Surveyor to complete: Reading, 2% or Less code, Downgrade Via Ventilation, instrument Type, Instrument #, Grade, Location/Remarks, Date & Time Rechecked, Initials, Grade 3 Rchck Interval and Continue 4 Months.
Verifying Flag (V*): A "Y" will display below the previous grade if this leak is being rechecked at 4 month intervals due to a previous downgrade via ventilation.

Due Date: This is the absolute due date required by CPUC and P&E Standard Practices.

Instrument Type (*): H - hydrogen flame indicator; or C - combustion gas indicator

Dwn Via Vent: Enter Yes if the leak is downgraded via ventilation or No if not.

Cont 4 Mos: If the leak was downgraded via ventilation at least 12 months ago, enter Yes to continue 4 month recheck intervals or No to discontinue 4 month recheck intervals.

GR3 Rchk Interval: Enter the # of months for the grade 3 leak recheck interval, if different from next scheduled survey (e.g. 12, 18, 36, 60) if left blank, default will be the next scheduled survey after the current year survey.

2% CD: Enter the 2% reason code if the grade is 1, 2+ or 2 and the reading is 2% or less; A-Wall to wall and traveling, E-Next to, at or under building, C-Order next to public gathering location, D-in foreign structure, E-Audible and/or visible, F-Car (leak) in extremely poor condition.

G-At least second customer call out, H-Leak is reported as 0% Gas Visual, J Leak within the scope of work by others, S Leak is suspected to be on a copper service.

** Aform Printed for this leak. *** Grade 3 downgrade is not allowed.

Selection Criteria Division = Peninsula, District = Peninsula, Map = 3279, Plat = G01, Block = ALL, Grade = 2, Leak date ends on Oct 01, 2005, POC = ALL