



**Pacific Gas and
Electric Company**

Gas Transmission and Distribution Bulletin

Title: Gas Leak Survey Frequency Clarification

Check all appropriate boxes

<input type="checkbox"/> SAFETY ALERT	<input checked="" type="checkbox"/> GAS	<input checked="" type="checkbox"/> DISTRIBUTION	<input type="checkbox"/> SUBSTATION ENGR.
<input checked="" type="checkbox"/> MANDATORY COMPLIANCE	<input type="checkbox"/> ELECTRIC	<input checked="" type="checkbox"/> TRANSMISSION	<input type="checkbox"/> TRANS./SUB. M&C
<input type="checkbox"/> RECOMMENDED ACTIONS	<input type="checkbox"/> ESTIMATING	<input type="checkbox"/> OPERATIONS	<input type="checkbox"/> APPLICANT DESIGNER / CONSTRUCTION
<input type="checkbox"/> INFORMATIONAL/CLARIFICATION	<input type="checkbox"/> MAPPING	<input type="checkbox"/> SERVICE	

Purpose

The purpose of this bulletin is to bring required leak survey frequency interval definitions listed in UO Standard S4110 "Leak Survey and Repair of Gas Transmission and Distribution Facilities" in line with the code requirements of the United States Department of Transportation (49 CFR 192) and the California Public Utilities Commission (General Order 112E).

The contents of this bulletin shall be incorporated in the next revision of UO Standard 4110.

Changes

Leak Survey frequencies are defined as follows:

Semi-annual

Twice each year not to exceed 7 ½ months to the date

Annual

Once each calendar year not to exceed 15 months (formerly 14 months) to the date

3 Years

Once every three calendar years not to exceed 39 months (formerly 38 months) to the date

5 years

Once every five calendar years not to exceed 63 months (formerly 62 months) to the date

These definitions of leak survey frequencies are applicable immediately.

Approved by:

Robert Fassett

Date: 04/15/08

Author: [REDACTED]

If you have any questions about this bulletin, please call the employee(s) listed below:

Contact(s): [REDACTED]

LAN ID(s): [REDACTED]

Phone(s): Co. [REDACTED]

