

- 12.1.4 The chart must show a minimum of eight hours (except where a four hour test is permitted in Appendix A). Any discrepancies should be explained.
- 12.1.5 At the end of the test, the actual time, date, and initials of the person removing the chart must be shown on the face of the chart.
- 12.1.6 The section of pipe under test must be identified on the face of the chart, along with the job number.
- 12.1.7 The following additional information is to be shown on the back of the chart:
- 12.1.7.1 Job number
  - 12.1.7.2 Location of test
  - 12.1.7.3 Test pressure, date, and duration
  - 12.1.7.4 Size, wall thickness, pipe specification, and length of section tested
  - 12.1.7.5 The serial number of the recorder or other means of identification
  - 12.1.7.6 The date the recorder was last calibrated and serial number of the dead weight tester or other reference standard used.
- 12.1.8 The above information is to be recorded on the chart at the time of the test. After the test is completed, the supervisor is to review the chart and then sign and date it to verify that it complies with the requirements of this Standard.
- 12.1.9 The original of the test chart is to be attached to the original of the Strength Test Pressure Report Form 62-4921. A copy of the test chart is to be attached to each copy of the test report. This record is to be retained for the life of the facility.

### 13.0 TEST RECORDS FOR FACILITIES OPERATING AT OR UNDER 100 PSIG

For each facility operating at or under 100 psig, the test information shall be recorded in a box provided on the work order form or the gas service form. If these documents are not used, the test information shall be recorded on the as-built copy of the construction drawing. The test record shall be retained for the life of the facility.

DESIGN AND TEST REQUIREMENTS GAS STANDARD - PIPING - DATA SHEET	PG&E CO.	DRAWING NUMBER	REV.
	SHEET 7 OF 7 SHEETS	087950	2
61-4344 Rev 1-76		MICROFILM	