APPENDIX "H" EMERGENCY PIPE TEST INFORMATION FORM

THIS FORM IS TO BE COMPLETED SUBSEQUENT TO THE STRENGTH TEST & ATTACHED TO THE STRENGTH TEST PRESSURE REPORT.

PART 1: THIS INFORMATION IS AVAILABLE FROM THE COMPLETED STRENGTH TEST PRESSURE

LOCATION OF TEST DATE OF TEST DURATION OF TEST	HRS.	MIN.
PIPE SPECIFICATION (0.D. X W.T. X SMYS) FOOTAGE TESTED	÷.	FT.
TEST PRESSURE		PSIG

PART II: FOR A GIVEN CLASS LOCATION, THIS PIPE MAY BE USED IN PIPELINE FACIL-THIS HAVING FUTURE DESIGN PRESSURES UP TO & INCLUDING THE PRESSURE CALCULATED IN THE "MAXIMUM PRESSURE" COLUMN.

					ALLOWABLE USE*			
CLASS LOCATION	DESIGN FACTOR(F)	TEST FACTOR	LIMITED BY DESIGN FACTOR () PSIG	LIMITED BY TEST PRESSURE (2) PSIG	MAXIMUM PRESSURE PSIG	CLASS LOCATION		
1	.72	1.25				I		
2	.60	1.50				2		
3	.50	1.50	-			3		
4	. 40	1.50				4		

**WHEN DETERMINING IF THE EMERGENCY PIPE IS QUALIFIED FOR A PARTICULAR GAS FACILITY (THE CLASS LOCATION & DESIGN FACTOR ARE SPECIFIED), THE DESIGN FACTOR OF THE GAS FACILITY MUST BE COMPARED TO THE DESIGN FACTORS (ISTED IN THE CHART. FOR CERTAIN TYPES OF GAS FACILITIES, THE DESIGN FACTORS ARE LESS THAN THOSE IN THE CHART. IF THE DESIGN FACTORS ARE DIFFERENT, (1) MUST BE RECALCULATED USING THE CORRECT DESIGN FACTOR, THEN COMPARED TO (2). THE SMALLER OF (1) AND (2) WILL BE THE NEW * MAXIMUM PRESSURE.*

(1) = $\frac{2 \times SMYS (psi) \times w.t. (inch)}{2 \times F} \times F$ 0.D. (inch)

(2) = TEST PRESSURE (FROM PART 1)
TEST FACTOR

MAXIMUM PRESSURE - THE SMALLER OF (1) AND (2)

___ DATE__ NAME_

CADD 821490 01		2			Ţ			
N114			REVISED PAGE NO.	JRC	ATG.		G) 2000	ال ليست
		1-20-83 DATE	ISSUED FOR USE DESCRIPTION	DWN	CHKD.			الممية
GM SUPV			PIPING-DATA SHEET		SUPERSE			
DSGN DWN MD STEPHAN			TESTING OF EMERGENCY PIPE		SUPERSEDED BY SHEET NO. 1 OF 1 SHEETS			
		HAN		1				
CHKD O K			GAS STANDARD	- 1	DRAWIN			REV
DATE 10-25-82		CALE ONE	PACIFIC GAS AND ELECTRIC COMPANY SAN FRANCISCO, CALIFORNIA		2	343	800	2
61-4346 REV.7-78					MICROFI	LM		

GTR0042551 Material Redacted