



Megan Caulson
SDG&E Regulatory Tariffs Manager
8330 Century Park Court
San Diego, CA 92123-1548

Tel: 858-654-1748
Fax: 858-654-1788

February 28, 2011

Paul Clanon
Executive Director
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102

Re: San Diego Gas & Electric Company (SDG&E) Electric System Reliability Annual Report
for 2010

Dear Mr. Clanon,

Pursuant to Ordering Paragraph (OP) 1 of D.96-09-045, SDG&E hereby submits its Electric System Reliability Report for the calendar year ended December 31, 2010.

SDG&E is currently in the process of filing an Advice Letter pursuant to a request from the Energy Division proposing that the criteria of major event days be changed from those contained in D. 96-09-045 to those contained in IEEE 1366-2003. Accordingly, this report provides SDG&E's Historical System Reliability Data based on IEEE 1366 exclusion criteria (shown on Page 2), in addition to the Historical System Reliability Data based on D. 96-09-045 exclusion criteria (shown on Page 1).

If there are any questions concerning the enclosed information, please contact Megan Caulson at (858) 654-1748.

Sincerely,

Megan Caulson
Regulatory Tariff Manager

Encl.

cc: Julie Fitch, Energy Division
David Lee, Energy Division
Mike Olson, SDG&E



A  Sempra Energy utility[®]

ELECTRIC SYSTEM RELIABILITY ANNUAL REPORT

2010



**Prepared for
California Public Utilities Commission**

February 24, 2011

EXECUTIVE SUMMARY

This Electric System Reliability Annual Report for 2010 has been prepared in response to CPUC Decision 96-09-045. This Decision established additional reliability recording, calculation, and reporting requirements for SDG&E.

The data in this report is presented in tabular form. All statistics and calculations include forced transmission, substation, and distribution outages, and exclude planned outages. Forced outages are those that are not prearranged. For the purposes of this report, sustained outages are those outages that lasted 5 minutes or more in duration, while momentary outages are those outages that lasted less than 5 minutes in duration.

The reliability indicators that are tracked are as follows:

1. SAIDI (System Average Interruption Duration Index) - minutes of sustained outages per customer per year.
2. SAIFI (System Average Interruption Frequency Index) - number of sustained outages per customer per year.
3. MAIFI (Momentary Average Interruption Frequency Index) - number of momentary outages per customer per year.
4. SAIDET* (System Average Interruption Duration Index Exceeding Threshold) - minutes of sustained outages per customer per year exceeding a defined annual threshold of 150 minutes.
5. ERT* (Estimated Restoration Time) - sum of the weighted accuracy of each outage divided by the number of customers who experienced an outage. Weighted accuracy is determined by using the time in play and number of customers who received accurate estimates.

The measurement of each reliability performance indicator excludes CPUC major events and events that are the direct result of failures in the ISO-controlled bulk power market, or non-SDG&E owned transmission and distribution facilities. A Major Event is defined in CPUC Decision 96-09-045 as an event that meets at least one of the following criteria:

- (a) The event is caused by earthquake, fire, or storms of sufficient intensity to give rise to a state of emergency being declared by the government, or
- (b) Any other disaster not in (a) that affects more than 15% of the system facilities or 10% of the utility's customers, whichever is less for each event.

* Introduced as new reliability indices in 2008 as a result of SDGE's General Rate Case Application:
(A) 06-12-009 and resulting decision (D) 08-07-046

This report also provides SDG&E's Historical System Reliability Data based on IEEE 1366 exclusion criteria (shown on Page 2), in addition to the Historical System Reliability Data based on D. 96-09-045 exclusion criteria (shown on Page 1).

A summary of 2010 performance is as follows:

CRITERIA	SAIDI	SAIFI	MAIFI	SAIDET	ERT
Including CPUC Major Events (2010)	89.77	0.863	0.507	–	–
Excluding CPUC Major Events (2010)	67.74	0.543	0.428	35.82	54%
10-Year Average (2001-2010) Including CPUC Major Events	105.59	0.691	0.589	–	–
10-Year Average (2001-2010) Excluding CPUC Major Events	64.09	0.596	0.569	–	–

The CPUC Major Events that were declared in 2010 are shown in the following table. Restricted access by a governmental agency that precludes or otherwise delays outage restoration times are considered CPUC Major Events and excluded from reliability results.

Month/Day	SAIDI	SAIFI	Sustained Customer Impact	MAIFI	Momentary Customer Impact	Event Cause(s)
January 18	12.61	0.085	117,558	0.066	90,520	Heavy Rain Storm; Major Event Exclusion 10% of Customers
January 22	0.01	0.000	34	-	-	Non-SDG&E Facility; SCE Outage
January 23	0.00	0.000	34	-	-	Non-SDG&E Facility; SCE Outage
February 8	0.03	0.000	55	0.000	3,459	Motor Vehicle Contact; SDPD Request to De-energize
April 1	4.40	0.211	290,945	-	-	Load Curtailment (ISO Ordered)
April 22	0.03	0.000	511	-	-	Motor Vehicle Injuries; SDPD Request to De-energize
July 14	-	-	-	-	34	Non-SDG&E Facility; SCE Outage
July 15	-	-	-	-	34	Non-SDG&E Facility; SCE Outage
August 23	0.00	0.000	33	-	-	Non-SDG&E Facility; SCE Outage
August 26	-	-	-	-	33	Non-SDG&E Facility; SCE Outage
November 19	0.00	0.000	4	-	-	Bomb Threat; SDPD Request to De-energize
December 20	4.93	0.023	31,376	0.014	18,904	Heavy Rain Storm; State of Emergency

In 2010, approximately 305 customers within SDG&E's service territory experienced more than one 5 minute (or longer) outage per month on a rolling annual average basis, after exclusion of CPUC Major Events.

TABLE OF CONTENTS

HISTORICAL SYSTEM RELIABILITY DATA (USING D.96-09-045 EXCLUSION CRITERIA).....	1
HISTORICAL SYSTEM RELIABILITY DATA (USING IEEE 1366 EXCLUSION CRITERIA).....	2
TEN LARGEST OUTAGE EVENTS IN 2010*	3
TEN LARGEST OUTAGE EVENTS IN 2009*	4
TEN LARGEST OUTAGE EVENTS IN 2008*	5
TEN LARGEST OUTAGE EVENTS IN 2007*	6
TEN LARGEST OUTAGE EVENTS IN 2006*	7
TEN LARGEST OUTAGE EVENTS IN 2005*	8
TEN LARGEST OUTAGE EVENTS IN 2004*	9
TEN LARGEST OUTAGE EVENTS IN 2003*	10
TEN LARGEST OUTAGE EVENTS IN 2002*	11
TEN LARGEST OUTAGE EVENTS IN 2001*	12
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2010	13
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2009	16
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2008	17
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2007	18
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2006	21
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2005	22
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2004	25
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2003	26
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2002	29
EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2001	33
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2010.....	35

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2009.....	36
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2008.....	37
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2007.....	38
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2006.....	39
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2005.....	40
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2004.....	41
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2003.....	42
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2002.....	43
CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2001.....	44

HISTORICAL SYSTEM RELIABILITY DATA (USING D.96-09-045 EXCLUSION CRITERIA)

Year	All Forced Interruptions Included			CPUC Major Events Excluded				
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI	No. of Events	Event Cause(s)
2001	68.57	0.870	0.865	52.87	0.636	0.858	7	Fires (2), Load Curtailment (4), and Interruptions Due to Non-SDG&E Facilities (1)
2002	82.68	0.813	0.606	77.35	0.807	0.604	4	Fires (2), Interruptions Due to Non-SDG&E Facilities (2)
2003	298.45	0.860	0.869	76.14	0.717	0.845	2	Firestorm 2003 (1), Wind Storm Affecting >15% of Facilities (1)
2004	93.19	0.672	0.614	78.75	0.615	0.610	5	Fires (3), Interruptions Due to Non-SDG&E Facilities (1), December Storm (1)
2005	61.99	0.637	0.602	58.46	0.567	0.568	10	Fires (4), Interruptions Due to Non-SDG&E Facilities (4), Storms (2)
2006	52.83	0.545	0.494	52.65	0.541	0.494	9	Fires (6), Interruptions Due to Non-SDG&E Facilities (3)
2007	182.17	0.590	0.572	52.00	0.481	0.527	8	State of Emergency Declared (2), Interruptions Due to Non-SDG&E Facilities (2), Load Curtailment (1), Request to De-energize/ Restricted Access (3)
2008	59.17	0.517	0.380	58.92	0.515	0.378	9	Fires (2), Request to De-energize/ Restricted Access (7)
2009	67.06	0.542	0.380	66.01	0.538	0.380	4	Fires (1), Interruptions Due to Non-SDG&E Facilities (1), Request to De-energize/ Restricted Access (2)
2010	89.77	0.863	0.507	67.74	0.543	0.428	12	Storms (2), Interruptions Due to Non-SDG&E Facilities (6), Load Curtailment (1), Request to De-energize/ Restricted Access (3)

HISTORICAL SYSTEM RELIABILITY DATA (USING IEEE 1366 EXCLUSION CRITERIA)

Year	All Forced Interruptions Included			Threshold Major Event Days Excluded *		
	SAIDI	SAIFI	MAIFI	SAIDI	SAIFI	MAIFI
2001	68.57	0.870	0.865	57.62	0.717	0.858
2002	82.68	0.813	0.606	70.71	0.621	0.588
2003	298.45	0.860	0.869	81.49	0.698	0.856
2004	93.19	0.672	0.614	78.83	0.619	0.610
2005	61.99	0.637	0.602	61.99	0.637	0.602
2006	52.83	0.545	0.494	52.83	0.545	0.494
2007	182.17	0.590	0.572	54.89	0.477	0.530
2008	59.17	0.517	0.380	59.17	0.517	0.380
2009	67.06	0.542	0.380	49.71	0.466	0.362
2010	89.77	0.863	0.507	63.36	0.520	0.441

* Per IEEE Standard 1366-2003 "2.5 beta method" for determining excludable days, days are excluded from a given year's metric if their SAIDI exceeds 2.5 times the standard deviation of daily SAIDI over the previous five year period.

TEN LARGEST OUTAGE EVENTS IN 2010*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	January 18 - 22	Heavy Rain Storm	12.61	0.085	Yes	117,558	1,752	Not Available
2	December 20 - 23	Heavy Rain Storm	4.93	0.023	Yes	31,376	1,758	Not Available
3	April 1	ISO Ordered Load Curtailment	4.40	0.211	Yes	290,945	43	Not Available
4	September 30 - October 5	Heavy Rain and Lightning Storm	2.88	0.036	No	50,155	1,343	Not Available
5	January 5 - 6	Faulted Tee	1.57	0.004	No	5,111	760	Not Available
6	September 26 - 28	Heat Storm	1.42	0.010	No	13,531	624	Not Available
7	September 30 - October 1	Vehicle Contact	1.34	0.004	No	5,503	1,074	Not Available
8	October 21	Vehicle Contact	1.33	0.002	No	2,753	1,341	Not Available
9	April 4 - 5	Earthquake	1.22	0.003	No	4,512	651	Not Available
10	October 19 - 20	Heavy Rain and Lightning Storm	1.12	0.014	No	18,873	718	Not Available

*Based on SAIDI impact.

TEN LARGEST OUTAGE EVENTS IN 2009*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	December 7 - 10	December Storm**	11.68	0.045	No	61,783	3,624	Not Available
2	December 13 - 14	Overhead Equipment Failure	4.49	0.016	No	21,956	1,099	Not Available
3	August 20 - 21	Vehicle Contact	1.05	0.004	Yes	5,031	970	Not Available
4	June 3 - 4	Lightning Storm	0.97	0.006	No	7,909	1,204	Not Available
5	February 9 - 10	Heavy Rain and Snow Storm	0.86	0.009	No	12,304	1,686	Not Available
6	December 7 - 8	Underground Equipment Failure**	0.60	0.003	No	3,889	1,082	Not Available
7	November 18 - 19	Faulted Cable	0.53	0.003	No	4,322	950	Not Available
8	November 28 - 29	Heavy Rain Storm	0.50	0.006	No	8,779	756	Not Available
9	November 23 - 24	Underground Equipment Failure	0.48	0.003	No	4,045	544	Not Available
10	November 9 - 10	Heavy Equipment Dig-In	0.47	0.005	No	7,458	1,167	Not Available

* Based on SAIDI impact.

** The information for both the Dec. 7-10 and Dec. 7-8 events have been updated. An underground equipment failure was inadvertently associated with the December storm event. This had no impact on the filed SAIDI, SAIFI, and MAIFI impacts when excluding CPUC events.

TEN LARGEST OUTAGE EVENTS IN 2008*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	December 17 - 22	Heavy Rain and Snow Storm throughout Service Territory, Part II	3.51	0.010	No	13,113	6,783	Not Available
2	January 5 - 8	Rain & Lightning Storm throughout Service Territory	1.33	0.011	No	15,438	1,731	Not Available
3	December 15	Heavy Rain and Snow Storm throughout Service Territory, Part I	1.02	0.006	No	8,421	421	Not Available
4	May 31	C138 & HC3 Tree Contact (also affecting C139 & 4kVs)	0.92	0.003	No	3,735	746	Not Available
5	October 19	C213 - Damaged Underground Cable	0.91	0.001	No	2,035	942	Not Available
6	June 22 - 23	C990 - Faulted Terminator	0.67	0.002	No	2,198	870	Not Available
7	April 8 - 9	C486 - Motor Vehicle Contact, Terminator and Cable Replaced	0.61	0.003	No	4,708	910	Not Available
8	December 25 - 26	C286 & EN2 - Multiple Circuits affected during Restoration	0.58	0.004	No	5,364	601	Not Available
9	May 23	C159 - Pothead Failure	0.56	0.002	No	3,178	298	Not Available
10	September 24	Bank 20 Bad Relay affecting circuits WA3, WA4, WA5 and WA6	0.56	0.004	No	6,128	178	Not Available

*Based on SAIDI impact.

TEN LARGEST OUTAGE EVENTS IN 2007*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	October 21 - November 24	Firestorm 2007 - Declaration of State of Emergency	128.42	0.055	Yes	74,088	40,453	Not Available
2	September 1 - 4	HEATWAVE 2007 (Labor Day Weekend)	1.59	0.010	No	13,662	833	Not Available
3	October 22	ISO Request - Load Curtailment during Firestorm 2007	1.18	0.051	Yes	68,826	34	Not Available
4	June 04	Laguna Niguel Outages - Faulted CB impacted Bus	1.15	0.016	No	21,425	254	Not Available
5	August 30	TL 629 & TL 6946 Lightning Contact on Swi 629-8	1.09	0.003	No	4,117	359	Not Available
6	July 28	Circuit 582 Underground Cable Failure	1.01	0.002	No	2,761	606	Not Available
7	October 11	Paradise Substation Bank 42 Lightning Arrestor Failure	0.80	0.017	No	23,121	85	Not Available
8	September 15 - 17	Circuit 221 Pine Valley Fire	0.77	0.000	No	585	2,942	Not Available
9	January 12 - 13	Circuits WA3, WA4, and UP1 - Downed Overhead Conductor	0.66	0.003	No	4,052	347	Not Available
10	December 25 - 26	Circuit EOS2 - Connector Failure	0.57	0.001	No	1,349	614	Not Available

*Based on SAIDI impact.

**The information for the largest event was inadvertently under reported in the 2007 annual report and has since been corrected above. This had no impact on the filed SAIDI, SAIFI, and MAIFI impacts when excluding CPUC events.

TEN LARGEST OUTAGE EVENTS IN 2006*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	July 22 - 23**	Heat Storm	2.89	0.020	No	26,477	1,280	Not Available
2	March 10 - 14	Storm / Winds	1.98	0.003	No	4,501	4,160	Not Available
3	July 21	TL 685 - Misoperation of a Relay (7 Substations)	1.84	0.033	No	45,007	55	Not Available
4	July 15 - 17	Lighting/ Heat Storm	1.03	0.009	No	12,048	869	Not Available
5	January 2 - 3	Storm / Winds	0.68	0.011	No	15,329	811	Not Available
6	June 15	Circuits 416 and 76 Private Motor Vehicle Contact	0.60	0.002	No	3,124	644	Not Available
7	September 6 - 7	Circuits 509 and 506 Private Motor Vehicle Contact	0.53	0.002	No	2,908	946	Not Available
8	May 23	Circuit 592 Damaged Connector Failure	0.49	0.002	No	3,246	397	Not Available
9	May 26	Circuit 1077 Private Motor Vehicle Contact	0.42	0.002	No	2,158	636	Not Available
10	July 31 - August 1	Circuit WY1 - Vegetation Contact	0.42	0.001	No	1,070	1,058	Not Available

* Based on SAIDI impact.

** Includes outages initiated on July 23rd and restored on July 24th.

TEN LARGEST OUTAGE EVENTS IN 2005*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	September 19	September Storm	2.78	0.015	No	19,399	1,447	Not Available
2	July 28	Laguna Niguel Transmission Event	1.57	0.028	No	37,267	72	Not Available
3	August 25	Poway, Escondido, Cannon Sub - Load Curtailment	1.36	0.039	Yes	51,411	51	Not Available
4	February 18	February Storms	1.35	0.024	Yes	31,885	2,495	Not Available
5	July 23	Lightning Storm July	1.20	0.013	No	17,309	1,450	Not Available
6	October 6	Damaged OH Switch	0.89	0.004	No	5,226	468	Not Available
7	April 22	Poway Sub	0.89	0.008	No	10,896	108	Not Available
8	February 22	Vehicle Contact	0.82	0.003	No	4,143	310	Not Available
9	February 2	Feb 2nd storm	0.77	0.005	No	6,361	904	Not Available
10	January 3	January Storms	0.75	0.005	Yes	7,156	2,146	Not Available

*Based on SAIDI impact.

TEN LARGEST OUTAGE EVENTS IN 2004*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	Dec. 28 - 31	December 2004 Storm	14.41	0.056	Yes	74,000	2,074	Not Available
2	Dec. 1	Substation - Equipment Failure	2.88	0.017	No	22,716	393	Not Available
3	Jun. 12	Substation - Animal Contact	2.16	0.011	No	14,708	204	Not Available
4	Jan. 23 - 24	Conductor Failure	1.88	0.003	No	3,951	625	Not Available
5	Sep. 30 - Oct. 1	Private Vehicle Contact	1.51	0.003	No	4,322	459	Not Available
6	Oct. 17 - 21	Storm / Winds	1.24	0.013	No	16,833	1,026	Not Available
7	Dec. 5	Private Vehicle Contact	1.14	0.005	No	6,292	276	Not Available
8	Dec. 5	Connector Failure	1.10	0.004	No	5,824	502	Not Available
9	Nov. 10	Transmission Equipment Failure	0.82	0.004	No	5,095	414	Not Available
10	Dec. 5 - 6	Storm / Winds	0.78	0.001	No	1,265	808	Not Available

*Based on SAIDI impact.

TEN LARGEST OUTAGE EVENTS IN 2003*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	Oct. 26 - Nov. 25	Firestorm 2003	193.33	0.071	Yes	91,443	43,032	Not Available
2	Jan. 6 - 8	Storm / Winds	28.98	0.072	Yes	92,715	2,548	Not Available
3	Oct. 27 - 28	Substation - Animal Contact	3.10	0.017	No	22,285	227	Not Available
4	Dec. 25 - 26	Storm / Winds	3.00	0.017	No	21,611	1,303	Not Available
5	May 14 - 15	Transmission Line - Heavy Equipment Contact (Crane)	1.47	0.002	No	2,900	1,832	Not Available
6	Mar. 28 - 30	Storm / Winds	1.25	0.003	No	3,767	1,440	Not Available
7	Sep. 2 - 3	Storm / Winds	1.06	0.014	No	18,025	678	Not Available
8	Oct. 5 - 6	Underground Cable Failure	0.97	0.004	No	5,255	841	Not Available
9	Jan. 12	Substation - Animal Contact	0.97	0.014	No	17,990	73	Not Available
10	Sep. 19 - 20	Underground Cable Failure	0.88	0.004	No	5,334	1,010	Not Available

*Based on SAIDI impact.

TEN LARGEST OUTAGE EVENTS IN 2002*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC Major Event?	Total Number of Customers Affected	Longest Customer Interruption (minutes)	Number of People Used to Restore Service
1	Feb. 27	Accidental Trip of Circuit Breaker	6.00	0.173	No	219,522	62	Not Available
2	Feb. 9 - 11	Storm / Winds	3.41	0.023	No	28,987	1,587	Not Available
3	Feb. 10 - 13	Fallbrook (Gavilan) Fire - Request by CDF	2.99	0.003	Yes	3,732	4,107	Not Available
4	Aug. 31 - Sep. 3	Storm / Heat	2.94	0.023	No	28,836	775	Not Available
5	July 29 - Aug. 12	Pines Wildland Fire - State of Emergency	2.34	0.003	Yes	3,498	10,227	Not Available
6	Nov. 25 - 30	Storm / Winds	2.16	0.014	No	18,108	1,493	Not Available
7	Apr. 5	Circuit Breaker Failure	1.79	0.008	No	10,591	306	Not Available
8	Apr. 22 - 23	Crossarm Failure	1.35	0.004	No	5,219	603	Not Available
9	Dec. 16 - 18	Storm / Winds	1.23	0.008	No	10,078	1,106	Not Available
10	July 23 - 24	Switch Faulted / Mechanical	1.07	0.006	No	7,284	586	Not Available

*Based on SAIDI impact.

TEN LARGEST OUTAGE EVENTS IN 2001*

Rank	Date	Description	SAIDI Impact	SAIFI Impact	CPUC	Total Number of Customers Affected	Longest Customer Interruption Duration	Number of People Used to Restore Service
1	March 19	Load curtailment - ISO request	10.91	0.153	Yes	191,146	164	Not Available
2	March 20	Load curtailment - ISO request	3.74	0.063	Yes	78,446	71	Not Available
3	July 17	Remedial Action Scheme inadvertently interrupted customers	1.21	0.121	No	150,959	40	Not Available
4	May 22	Substation - Animal contact	0.79	0.009	No	11,238	88	Not Available
5	January 11	Storm/winds	0.73	0.006	No	6,988	1,886	Not Available
6	February 13	Storm/winds	0.70	0.003	No	3,541	728	Not Available
7	April 07	Private vehicle contact	0.69	0.002	No	1,939	874	Not Available
8	May 29	Transmission Line - Bird contact	0.66	0.012	No	14,996	120	Not Available
9	May 08	Load curtailment - ISO request	0.64	0.012	Yes	14,730	81	Not Available
10	January 10	Underground cable failure	0.64	0.002	No	2,330	501	Not Available

*Based on SAIDI impact.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2010

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*																				
			0	2	4	6	8	10	12	14	16												
January 18 - 22	Heavy Rain Storm	117,558	0	0	0	0	0	0	4,482	12,271	4,618	Customers Interrupted - Hours Into the Event Day (continued)											
			18	20	22	24	26	28	30	32	34	4,974	884	568	491	492	489	483	565	110	Customers Interrupted - Hours Into the Event Day (continued)		
			36	38	40	42	44	46	48	50	52	50,447	26,607	10,492	7,046	5,131	4,272	993	797	517	Customers Interrupted - Hours Into the Event Day (continued)		
			54	56	58	60	62	64	66	68	70	269	279	115	91	8,380	4,603	2,138	754	753	Customers Interrupted - Hours Into the Event Day (continued)		
			72	74	76	78	80	82	84	86	88	385	385	18,984	15,114	6,600	30,186	10,106	13,140	3,475	Customers Interrupted - Hours Into the Event Day (continued)		
			90	92	94	96	98	100	102	104	106	2,352	2,806	4,638	448	102	17,158	18,330	5,084	420	Customers Interrupted - Hours Into the Event Day (continued)		
			108	110	112	114	116	118	120	122	124	490	465	3,093	271	155	0	0	0	0	Customers Interrupted - Hours Into the Event Day (continued)		

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2010
EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*									
			0	2	4	6	8	10	12	14	16	
April 1	ISO ordered mandatory load curtailment	290,945	290,945	0	0	0	0	0	0	0	0	0

**EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2010
EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*											
			0	5	10	15	20	25	30	35	40			
December 20 - 23	Heavy Rain Storm	31,376	0	110	5,326	12,271	7,252	4,618	2,769	4,974	2,983			
			Customers Interrupted - Hours Into the Event Day (continued)											
			45	50	55	60	65	70	75	80	85			
			884	884	568	593	491	517	492	492	489			
			Customers Interrupted - Hours Into the Event Day (continued)											
			90	95	100	105	110	115	120	125	130			
			489	483	474	565	583	110	24,456	50,447	38,085			
			Customers Interrupted - Hours Into the Event Day (continued)											
			135	140	145	150	155	160	165	170	175			
			26,607	15,698	10,492	9,863	7,046	6,168	5,131	4,325	4,272			
			Customers Interrupted - Hours Into the Event Day (continued)											
			180	185	190	195	200	205	210	215	220			
			3,146	993	967	797	793	517	780	269	269			
			Customers Interrupted - Hours Into the Event Day (continued)											
			225	230	235	240	245	250	255	260	265			
			279	276	115	116	91	5,061	8,380	7,127	4,603			
			Customers Interrupted - Hours Into the Event Day (continued)											
			270	275	280	285	290	295	300	305	310			
			2,380	2,138	772	754	754	753	731	385	385			
Customers Interrupted - Hours Into the Event Day (continued)														
315	320	325	330	335	340	345	350	355						
385	7,378	18,984	16,315	15,114	7,157	0	0	0						

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2009
EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*												
			2	4	6	8	10	12	14	16	18				
August 20 - 21	Vehicle Contact	5,031	0	0	0	0	0	0	0	0	0	0	0	0	
			Customers Interrupted - Hours Into the Event Day (continued)												
			20	22	24	26	28	30	32	34	36				
			0	5,031	2,958	1,102	1,102	1,102	1,102	1,102	1,102	1,102			
			Customers Interrupted - Hours Into the Event Day (continued)												
			38	40	42	44	46	48	50	52	54				
			1,102	0	0	0	0	0	0	0	0	0			

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2008
EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

There were no CPUC Major Events from 2008 to be extracted.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2007

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			0	5	10	15	20	25	30	35	40
October 21 - November 24	Firestorm 2007 - Declaration of State of Emergency	74,088	0	0	994	5,847	1,439	4,016	26,645	25,770	23,560
			Customers Interrupted - Hours Into the Event Day (continued)								
			45	50	55	60	65	70	75	80	85
			21,810	21,651	16,940	21,349	17,522	18,435	17,213	17,263	20,582
			Customers Interrupted - Hours Into the Event Day (continued)								
			90	95	100	105	110	115	120	125	130
			18,341	17,699	17,699	17,927	17,503	14,693	14,012	13,117	13,064
			Customers Interrupted - Hours Into the Event Day (continued)								
			135	140	145	150	155	160	165	170	175
			11,787	10,935	9,682	8,676	8,640	7,881	6,755	6,503	7,801
			Customers Interrupted - Hours Into the Event Day (continued)								
			180	185	190	195	200	205	210	215	220
			6,582	5,670	4,791	4,786	5,154	4,700	4,702	4,104	4,104
			Customers Interrupted - Hours Into the Event Day (continued)								
			225	230	235	240	245	250	255	260	265
			4,111	4,105	3,010	2,862	2,862	2,862	3,455	3,568	2,911
			Customers Interrupted - Hours Into the Event Day (continued)								
			270	275	280	285	290	295	300	305	310
			2,725	2,986	3,008	2,303	2,303	2,358	2,277	3,211	1,946
			Customers Interrupted - Hours Into the Event Day (continued)								
315	320	325	330	335	340	345	350	355			
1,882	1,882	2,141	2,107	1,825	1,825	1,825	2,296	1,734			
Customers Interrupted - Hours Into the Event Day (continued)											
360	365	370	375	380	385	390	395	400			
1,540	1,540	2,657	1,472	1,506	1,211	2,292	1,255	1,985			

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**The total customer impact as well as customers out of service for hours 35, 45, and 50 were inadvertently incorrectly reported and have since been corrected. This had no impact on the filed SAIDI, SAIFI, and MAIFI impacts for Non-CPUC events.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2007
EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day (continued)								
			405	410	415	420	425	430	435	440	445
October 21 - November 24	Firestorm 2007 - Declaration of State of Emergency (Continued)	74,088	1,036	987	987	994	861	721	721	811	692
			Customers Interrupted - Hours Into the Event Day (continued)								
			450	455	460	465	470	475	480	485	490
			883	410	410	456	504	225	225	225	216
			Customers Interrupted - Hours Into the Event Day (continued)								
			495	500	505	510	515	520	525	530	535
			49	9	6	6	6	6	6	6	6
			Customers Interrupted - Hours Into the Event Day (continued)								
			540	545	550	555	560	565	570	575	580
			31	31	6	6	6	6	6	6	6
			Customers Interrupted - Hours Into the Event Day (continued)								
			585	590	595	600	605	610	615	620	625
			6	6	6	6	6	6	6	6	6
			Customers Interrupted - Hours Into the Event Day (continued)								
			630	635	640	645	650	655	660	665	670
			6	6	6	6	6	6	6	6	6
			Customers Interrupted - Hours Into the Event Day (continued)								
			675	680	685	690	695	700	705	710	715
			6	6	6	6	6	6	6	6	6
			Customers Interrupted - Hours Into the Event Day (continued)								
720	730	740	750	760	770	780	790	800			
0	0	0	0	0	0	0	0	0			
Customers Interrupted - Hours Into the Event Day (continued)											
810	815	820	825	830	835	840	845	850			
0	30	30	60	0	0	0	0	0			

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**The total customer impact as well as customers out of service for hours 35, 45, and 50 were inadvertently incorrectly reported and have since been corrected. This had no impact on the filed SAIDI, SAIFI, and MAIFI impacts for Non-CPUC events.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2007

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
October 22	ISO Request - Load Curtailment during Firestorm 2007	68,826	0	0	0	0	0	0	0	68,826	0
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			0	0	0	0	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2006

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

There were no CPUC Major Events from 2006 to be extracted.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2005

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
January 3 - January 13	January Storms - Declaration of State of Emergency	7,156	0	0	0	0	0	25	68	43	123
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	38	40	42	44	110	112	114	116
			25	194	183	176	25	1,075	1,762	110	55
			Customers Interrupted - Hours Into the Event Day (continued)								
			118	120	130	132	134	136	166	168	170
			0	55	55	55	55	12	55	70	70
			Customers Interrupted - Hours Into the Event Day (continued)								
			172	174	176	178	180	182	184	186	194
			0	110	820	0	0	0	0	55	25
			Customers Interrupted - Hours Into the Event Day (continued)								
			196	198	200	202	204	206	208	210	212
			1179	577	258	215	98	135	135	135	110
			Customers Interrupted - Hours Into the Event Day (continued)								
			214	216	218	220	222	224	226	228	230
			122	110	110	110	110	110	110	110	110
			Customers Interrupted - Hours Into the Event Day (continued)								
232	234	236	238	240	242	244	246	250			
110	110	110	110	110	0	0	0	0			

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**The customers interrupted were inadvertently reported in the incorrect time slot in 2005. This table has been corrected in 2007; the adjustment had no effect on the reported SAIDI and SAIFI impacts for these events.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2005

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	22	32	34	36
February 18 - February 25	February Storms - Declaration of State of Emergency	31,885	0	0	155	52	226	25	36	1,506	608
			Customers Interrupted - Hours Into the Event Day (continued)								
			38	40	42	44	46	48	50	52	54
			204	188	1,008	31	31	31	19	19	129
			Customers Interrupted - Hours Into the Event Day (continued)								
			56	58	60	62	64	66	68	70	72
			129	129	19	226	19	19	19	19	19
			Customers Interrupted - Hours Into the Event Day (continued)								
			74	76	78	80	82	84	86	88	90
			19	19	19	19	19	110	199	72	41
			Customers Interrupted - Hours Into the Event Day (continued)								
			92	94	96	104	108	110	112	114	124
			8	63	1	25	8	8	62	62	5067
			Customers Interrupted - Hours Into the Event Day (continued)								
			126	128	130	132	134	160	162	164	166
191	690	577	19	1	84	358	860	540			
Customers Interrupted - Hours Into the Event Day (continued)											
168	170	172	174	176	178	180	182	184			
460	234	87	31	31	7	7	7	0			

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**The customers interrupted were inadvertently reported in the incorrect time slot in 2005. This table has been corrected in 2007; the adjustment had no effect on the reported SAIDI and SAIFI impacts for these events.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2005

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*									
			2	4	6	8	10	12	14	16	18	
August 25	ISO ordered mandatory load curtailment	51,411	0	0	0	0	0	0	0	0	51,411	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**The customers interrupted were inadvertently reported in the incorrect time slot in 2005. This table has been corrected in 2007; the adjustment had no effect on the reported SAIDI and SAIFI impacts for these events.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2004

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
December 28 - 31	December Storm - Declaration of State of Emergency	74,000	0	0	0	31	3,725	5	30	1,381	48,480
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			36,187	26,037	18,190	11,941	7,393	5,017	3,093	1,372	709
			Customers Interrupted - Hours Into the Event Day (continued)								
			38	40	42	44	46	48	50	52	54
			411	159	91	36	36	50	34	7	6
			Customers Interrupted - Hours Into the Event Day (continued)								
			56	58	60	62	64	66	68	70	72
			6	110	0	0	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2003

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
January 6 - 8	January Storm - >15% of System Facilities Affected	92,715	0	165	2,374	3,500	5,231	4,985	2,916	4,272	33
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			2,908	2,875	299	8,799	42,386	62,337	44,408	34,801	29,472
			Customers Interrupted - Hours Into the Event Day (continued)								
			38	40	42	44	46	48	50	52	54
			23,942	18,661	7,533	4,709	3,687	3,391	2,489	1,563	1,077
			Customers Interrupted - Hours Into the Event Day (continued)								
			56	58	60	62	64	66	68	70	72
			1,021	648	581	92	94	69	69	37	37
			Customers Interrupted - Hours Into the Event Day (continued)								
			74	76	78	80	82	84	86	88	90
			25	25	0	0	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

**EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2003
EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS**

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			0	5	10	15	20	25	30	35	40
October 26 - November 25	Firestorm 2003 - Declaration of State of Emergency	91,443	0	697	12,087	25,599	33,856	33,575	35,317	43,272	44,623
			Customers Interrupted - Hours Into the Event Day (continued)								
			45	50	55	60	65	70	75	80	85
			43,523	38,774	28,412	26,932	24,552	24,157	21,108	20,628	17,709
			Customers Interrupted - Hours Into the Event Day (continued)								
			90	95	100	105	110	115	120	125	130
			16,330	17,074	17,074	16,013	14,356	12,195	11,878	11,878	11,878
			Customers Interrupted - Hours Into the Event Day (continued)								
			135	140	145	150	155	160	165	170	175
			11,214	6,643	1,050	833	813	379	635	820	820
			Customers Interrupted - Hours Into the Event Day (continued)								
			180	185	190	195	200	205	210	215	220
			820	820	777	777	777	635	2,357	2,563	2,563
			Customers Interrupted - Hours Into the Event Day (continued)								
			225	230	235	240	245	250	255	260	265
			2,563	2,835	2,149	2,149	2,149	1,166	1,089	890	873
			Customers Interrupted - Hours Into the Event Day (continued)								
			270	275	280	285	290	295	300	305	310
			849	827	867	948	948	948	795	738	566
			Customers Interrupted - Hours Into the Event Day (continued)								
315	320	325	330	335	340	345	350	355			
535	535	432	432	432	432	432	324	312			
Customers Interrupted - Hours Into the Event Day (continued)											
360	365	370	375	380	385	390	395	400			
312	312	312	82	68	68	68	51	52			

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2003

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day (continued)								
			405	410	415	420	425	430	435	440	445
October 26 - November 25	Firestorm 2003 - Declaration of State of Emergency (continued)	91,443	49	49	49	49	49	49	49	49	49
			Customers Interrupted - Hours Into the Event Day (continued)								
			49	49	49	49	48	48	48	48	48
			Customers Interrupted - Hours Into the Event Day (continued)								
			48	48	48	48	48	48	48	48	48
			Customers Interrupted - Hours Into the Event Day (continued)								
			47	47	47	47	47	47	47	47	47
			Customers Interrupted - Hours Into the Event Day (continued)								
			48	40	40	40	40	40	40	40	40
			Customers Interrupted - Hours Into the Event Day (continued)								
			40	40	40	40	40	40	40	9	9
			Customers Interrupted - Hours Into the Event Day (continued)								
			9	9	9	9	9	9	9	9	9
			Customers Interrupted - Hours Into the Event Day (continued)								
			9	9	9	9	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2002

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
February 10 - 13	Fallbrook (Gavilan) Fire - Request by CDF	3,732	0	0	0	0	0	0	2,083	3,732	2,592
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			2,083	1,008	1,008	1,008	1,008	1,008	1,008	1,008	1,008
			Customers Interrupted - Hours Into the Event Day (continued)								
			38	40	42	44	46	48	50	52	54
			871	871	871	762	762	762	762	762	762
			Customers Interrupted - Hours Into the Event Day (continued)								
			56	58	60	62	64	66	68	70	72
			762	762	762	762	762	728	728	728	728
			Customers Interrupted - Hours Into the Event Day (continued)								
			74	76	78	80	82	84	86	88	90
			19	19	19	19	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2002

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
July 29 - August 12	Pines Wildland Fire - State of Emergency	3,498	0	0	0	0	0	0	0	3	3
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			338	338	338	338	338	338	338	338	866
			Customers Interrupted - Hours Into the Event Day (continued)								
			38	40	42	44	46	48	50	52	54
			794	794	338	338	338	338	338	338	338
			Customers Interrupted - Hours Into the Event Day (continued)								
			56	58	60	62	64	66	68	70	72
			338	338	338	338	338	338	338	338	338
			Customers Interrupted - Hours Into the Event Day (continued)								
			74	76	78	80	82	84	86	88	90
			338	338	338	338	338	338	338	338	3
			Customers Interrupted - Hours Into the Event Day (continued)								
			92	94	96	98	100	102	104	106	108
			3	3	3	3	3	3	3	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2002

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			110	112	114	116	118	120	122	124	126
July 29 - August 12	Pines Wildland Fire - State of Emergency	3,498	0	0	0	0	0	0	10	10	10
			Customers Interrupted - Hours Into the Event Day (continued)								
			128	130	132	134	136	138	140	142	144
			10	10	10	10	10	10	10	10	10
			Customers Interrupted - Hours Into the Event Day (continued)								
			146	148	150	152	154	156	158	160	162
			10	10	10	10	10	10	10	10	10
			Customers Interrupted - Hours Into the Event Day (continued)								
			164	166	168	170	172	174	176	178	180
			10	10	10	258	258	258	258	258	258
			Customers Interrupted - Hours Into the Event Day (continued)								
			182	184	186	188	190	192	194	196	198
			258	258	258	258	258	258	258	258	258
			Customers Interrupted - Hours Into the Event Day (continued)								
			200	202	204	206	208	210	212	214	216
			258	258	258	258	258	258	258	258	258
			Customers Interrupted - Hours Into the Event Day (continued)								
			218	220	222	224	226	228	230	232	234
			258	258	258	258	224	224	224	224	224

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2002

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day (continued)								
			236	238	240	242	244	246	248	250	252
July 29 - August 12	Pines Wildland Fire - State of Emergency	3,498	224	224	224	224	217	122	122	122	122
			Customers Interrupted - Hours Into the Event Day (continued)								
			254	256	258	260	262	264	266	268	270
			122	122	122	122	122	122	122	122	122
			Customers Interrupted - Hours Into the Event Day (continued)								
			272	274	276	278	280	282	284	286	288
			122	12	12	12	12	12	12	12	12
			Customers Interrupted - Hours Into the Event Day (continued)								
			290	292	294	296	298	300	302	304	306
			0	0	0	0	0	0	0	0	0
			308	310	312	314	316	318	320	322	324
			0	0	0	0	0	0	0	0	0
			Customers Interrupted - Hours Into the Event Day (continued)								
			326	328	330	332	334	336	338	340	342
			0	0	0	0	0	0	0	0	0
			Customers Interrupted - Hours Into the Event Day (continued)								
			344	346	348	350	352	354	356	358	360
			0	0	0	0	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2001

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
Mar. 19	Load curtailment - ISO request	191,146	0	0	0	0	0	30,590	68,143	28,067	0
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			0	0	0	0	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*								
			2	4	6	8	10	12	14	16	18
Mar. 20	Load curtailment - ISO request	78,446	0	0	0	0	11,181	10,189	10,838	0	0
			Customers Interrupted - Hours Into the Event Day (continued)								
			20	22	24	26	28	30	32	34	36
			0	0	0	0	0	0	0	0	0

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

EXCLUDABLE CPUC MAJOR EVENT DETAILS FOR 2001

EXTRACTED FROM THE TEN LARGEST OUTAGE EVENTS

Date of Outage	Description of Outage	Total Number of Customers Out of Service	Customers Interrupted - Hours Into the Event Day*									
			2	4	6	8	10	12	14	16	18	
May 8	Load curtailment - ISO request	14,730	0	0	0	0	0	0	0	7,409	0	
			Customers Interrupted - Hours Into the Event Day (continued)									
			20	22	24	26	28	30	32	34	36	
			0	0	0	0	0	0	0	0	0	

*Customers reflected in the time increments include all customers experiencing outages at that point in time. The event day begins at midnight.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2010

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	Northeast	221	290
November	Northeast/Eastern	221/444	289/15
December	Eastern	444	15

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2009

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2008

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2007

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2006

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2005

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2004

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2003

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	Northeast	212	62
February	Northeast	212	60
March	Northeast	212	60
April	Northeast	212	60
May	Northeast	212	60
June	Northeast	212	60
July	Northeast	212	60
August	Northeast	212	62
September	Northeast	212	62
October	Northeast	212	60
November	Northeast	212	60
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2002

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.

CUSTOMERS EXPERIENCING MORE THAN 12 SUSTAINED OUTAGES IN A ROLLING 12-MONTH PERIOD (EXCLUDING CPUC MAJOR EVENTS) FOR 2001

Month	District	Circuit	Number of Customers Experiencing >12 Sustained Outages
January	N/A	N/A	None
February	N/A	N/A	None
March	N/A	N/A	None
April	N/A	N/A	None
May	N/A	N/A	None
June	N/A	N/A	None
July	N/A	N/A	None
August	N/A	N/A	None
September	N/A	N/A	None
October	N/A	N/A	None
November	N/A	N/A	None
December	N/A	N/A	None

Data is based upon station outages as reported through SDG&E's Outage Management System.