

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

Orig. & Copy
to Secretary

Director

Numerical File

Alphabetical File

Accounting Officer

RETURN TO ELECTRIC DIVISION

R E S O L U T I O N

RESOLUTION NO. E-708

PUBLIC UTILITIES DEPARTMENT
DIVISION: **Electric**
DATE: **July 11, 1950**

SUBJECT: Authorization of Wood Barrier in Lieu of Prescribed Clearance of Transformers from Building - Rule 58.3-B2 of General Order No. 95.

WHEREAS: PACIFIC GAS AND ELECTRIC COMPANY having requested authorization, by letter of June 22, 1950, to use wood barriers on a transformer structure situated on the easterly side of the Van Ness-Fulton Alley approximately 240 feet north of Inyo Street in the City of Fresno, and

WHEREAS: The use of wood barriers is limited to those situations where clearances of certain wires and transformer cases are impracticable to obtain and then only on authorization of the Commission, as specified in Rule 58.3-B2 of the Commission's General Order No. 95, and

WHEREAS: It appears that suitable wood barriers will be the most practicable means of providing safety to the public and utility workmen at said location,

IT IS FOUND that the requested permission should be granted, and good cause appearing,

IT IS ORDERED that Pacific Gas and Electric Company be and is hereby granted authority to erect and maintain wood barriers substantially as shown on the sketch attached to its letter of June 22, 1950 for the existing three-pole transformer structure located on the easterly side of the Van Ness-Fulton Alley approximately 240 feet northerly from Inyo Street in the City of Fresno, one of said barriers to be placed on the easterly side of said transformer structure and extending from the transformer platform flooring to a point not less than 10 feet above such flooring, and one of said barriers comprising a wood boxing over and around the customer's metal trough for a horizontal distance of not less than 4 feet from any exposed or unprotected supply conductors supported by said transformer structure that are within 8 feet vertically above said metal trough.

The Secretary is directed to cause appropriate notice to be given said utility of the granting of this authorization.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 11th day of July, 1950, the following Commissioners voting favorably thereon:

**R. E. WITTELSTAEDT. JUSTUS F. CRAEMER,
IHA H. RCWELL, HAROLD P. HULS,
KENNETH POTTEE.**

R. J. Rajalich
Secretary