

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

- _____ Orig. & Copy to Secretary
- _____ Director
- _____ Numerical File
- _____ Alphabetical File
- _____ Accounting Officer

RETURN TO ELECTRIC DIVISION

R E S O L U T I O N

RESOLUTION NO. E-786

PUBLIC UTILITIES DEPARTMENT

DIVISION: Electric

DATE: July 15, 1952

SUBJECT: Permission to Deviate from the Provisions of Rule 54.6B of General Order No. 95.

WHEREAS: PACIFIC GAS AND ELECTRIC COMPANY having requested permission by letter of June 18, 1952 to deviate in certain particulars from the provisions of Rule 54.6B in accordance with its Drawing No. 028160, Requirements for Agricultural Power Service Pole, so that rigid metal conduit may be used as a covering for the ground wire, without the use of a suitable protective covering, and

WHEREAS: It appears that the proposed construction will not create undue hazards or a lessening of normal safety since it would be installed in the first 8 feet above ground and will not be within 8 feet of unprotected supply conductors,

IT IS HEREBY ORDERED that Pacific Gas and Electric Company be and hereby is granted permission to deviate from that provision of Rule 54.6B of General Order No. 95 which states that ground wires shall be covered throughout their length by a suitable protective covering, to the extent set forth in its letter of request dated June 18, 1952, and in its Drawing No. 028160, dated April 1952, Requirements for Agricultural Power Service Pole for Motors 200 hp or Larger.

The Secretary is directed to cause appropriate notice to be given said utility of the granting of this authorization.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 15th day of July, 1952, the following Commissioners voting favorably thereon:

R. E. MITTELSTAEDT, [REDACTED]
HAROLD P. HULS, KENNETH POTTER,
[REDACTED]

R. J. [Signature]
Secretary