

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

- \_\_\_\_\_ Orig. & Copy to Secretary
- \_\_\_\_\_ Director
- \_\_\_\_\_ Numerical File
- \_\_\_\_\_ Alphabetical File
- \_\_\_\_\_ Accounting Officer

RETURN TO ELECTRIC SECTION

R E S O L U T I O N

RESOLUTION NO. E-812

PUBLIC UTILITIES DEPARTMENT  
DIVISION: Electric  
DATE: August 4, 1953

SUBJECT: Permission to Deviate from the Provisions of Rule 58.3D of General Order No. 95.

WHEREAS: CALIFORNIA ELECTRIC POWER COMPANY having requested permission by letter of July 20, 1953, to deviate from certain provisions of Rule 58.3D to the extent that transformer cutouts, fuses, disconnects or switches installed prior to the effective date of this resolution have been installed with lesser clearances above the level of conductors of other circuits than those specified in Table 2, Cases 8 to 13 of General Order No. 95, and,

WHEREAS: The installation of such facilities with clearances less than those specified in General Order No. 95 resulted from a misinterpretation of Rule 58.3D and,

WHEREAS: To require applicant to provide clearances for transformer cutouts, fuses, disconnects, or switches above the levels of other conductors as specified in Table 2, Cases 8 to 13, for those facilities already installed would not be economically justifiable, and good cause appearing,

IT IS HEREBY ORDERED that permission be and it is hereby granted California Electric Power Company to deviate from Rule 58.3D to the extent that cutouts, fuses, disconnects or switches for transformers have been installed with clearances less than specified in Table 2, Cases 8 to 13, above conductors of other circuits prior to the effective date of this resolution and the continued maintenance of such lesser clearances will not constitute a violation of General Order No. 95, provided the clearances of such installations be not less than those specified in Rule 54.406.

The Secretary is directed to cause appropriate notice to be given said utility of the granting of this authorization.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 4th day of August, 1953, the following Commissioners voting favorably thereon:

R. L. MITTELSTAEDT, JUSTUS S. LEANDER,  
DORIS M. PULL, KENNETH P. ...

*R. J. ...*  
Secretary