

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

RETURN TO ELECTRIC SECTION

RESOLUTION NO. E-862

Orig. & Copy
to Secretary

PUBLIC UTILITIES DEPARTMENT

R E S O L U T I O N

DIVISION: Electric

DATE: September 14, 1954

Director

Numerical File

Alphabetical File

Accounting Officer

SUBJECT: Request to Deviate from Rules 51.6-A and 52.4-A of General Order No. 95 with Respect to Material for "High Voltage" Signs

WHEREAS: SOUTHERN CALIFORNIA EDISON COMPANY has requested permission to use "High Voltage" signs made of synthetic resins, and

WHEREAS: It appears that some synthetic materials are suitable for "High Voltage" signs, and in the absence of such permission the use of these materials would be a violation of Rules 51.6-A and 52.4-A of General Order No. 95, and

WHEREAS: The use of such materials may be of interest and value to all electric supply agencies, and

WHEREAS: It appears that safety to workmen and the public will not be lessened by the use of such materials and that the wording of Rules 51.6-A and 52.4-A of General Order No. 95 should be changed to permit their use, and good cause appearing,

IT IS HEREBY ORDERED that the words "corrosion-resisting metal" in the second paragraph of Rule 51.6-A and in the first paragraph of Rule 52.4-A of General Order No. 95 be changed to "weather and corrosion resisting material".

The Secretary is hereby directed to cause appropriate notice to be given the electric supply agencies of this change.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 14th day of September, 1954, the following Commissioners voting favorably thereon:

PETER E. MITCHELL, JUSTUS F. CRAEMER,
KENNETH POTTER, VERNE SCOGGINS.


Secretary