

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

Orig. & Copy
to Secretary

RETURN TO ELECTRIC SECTION

RESOLUTION NO. E-867

PUBLIC UTILITIES DEPARTMENT

DIVISION: Electric

DATE: November 30, 1954

R E S O L U T I O N

Director
Numerical File
Alphabetical File
Accounting Officer

SUBJECT: Request to Deviate from Rule 84.7 of General Order
No. 95 with Respect to Climbing Space

WHEREAS: WEST COAST TELEPHONE COMPANY has requested permission to
continue to maintain a reduced climbing space through its communi-
cation facilities in Del Norte County, and

WHEREAS: In the absence of such permission the reduced climbing
space would be a violation of Rule 84.7 of General Order No. 95, and

WHEREAS: It appears that safety to workmen and the public will not
be lessened in certain cases of a reduced climbing space on communi-
cation poles, and good cause appearing,

IT IS HEREBY ORDERED that West Coast Telephone Company may continue
to maintain existing climbing space less than 18 inches in width
where communication conductors are supported on an existing crossarm
at the top position on a pole in a rural district as defined by Rule
21 of General Order No. 95, and no supply conductors contact the pole
above the communication conductors.

I hereby certify that the foregoing Resolution was duly introduced, passed
and adopted at a regular session of the Public Utilities Commission of the State of
California, held on the 30th day of November, 1954, the following
Commissioners voting favorably thereon:

PETER E. MITCHELL,
KENNETH PORTER,
RAY E. UNDERHILL.

R. J. Pajalich
Secretary