

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

RESOLUTION NO. E-882

Copy for:

\_\_\_\_\_  
Orig. & Copy  
to Secretary

UTILITIES DIVISION  
SECTION: Electric  
DATE: March 21, 1955

R E S O L U T I O N

\_\_\_\_\_  
Director  
\_\_\_\_\_  
Numerical File  
\_\_\_\_\_  
Alphabetical File  
\_\_\_\_\_  
Accounting Officer

SUBJECT: Permission to Deviate from Rules 54.7-A and 54.7-A3b,  
General Order No. 95

WHEREAS: ANZA ELECTRIC COOPERATIVE, INC., having requested by letters of January 31, 1955 and February 24, 1955, permission to deviate under specified construction conditions from the provisions of General Order No. 95 which require that climbing space be maintained 4 feet vertically, both above and below each conductor level through which it passes, and the requirements of said order which relate to leaving certain pinholes in line arms and/or buckarms vacant, and

WHEREAS: In the absence of such permission, such construction would be a violation of Rules 54.7-A and 54.7-A3b of General Order No. 95, and

WHEREAS: It appears that under the certain limiting conditions under which the request is made, such construction will not provide less safety than is provided in the order, and that the requested permission should be granted, and good cause appearing,

IT IS HEREBY ORDERED that permission be granted to Anza Electric Cooperative, Inc. to deviate from Rules 54.7-A and 54.7-A3b of General Order No. 95 to the following extent and with the limiting conditions set forth below:

The requirement of Rule 54.7-A that climbing space shall be maintained for a distance of not less than 4 feet vertically, both above and below each conductor level through which it passes, and the requirements of Rule 54.7-A3b which relate to leaving certain pinholes in line arms and/or buckarms vacant, shall not be held to apply to a single circuit of more than 7,200 volts in horizontal configuration at the top of the pole, provided:

1. No portion of any conductor on the lower arm of related line and buckarm of such a circuit, or jumpers connected thereto, shall be a lesser radial distance from center line of pole than that required by Rule 37, Table 1, Case 6, and
2. Where line arm and related buckarm are present, climbing space as required by Rule 54.7-A2 shall be maintained through the level of the conductors on the lower arm for a distance of not less than 4 feet below such conductor, up to the level of conductors on the upper arm, but need not extend through the level of the conductors on the upper arm, and

RESOLUTION NO. 2-882

Copy for:

\_\_\_\_\_ Orig. & Copy  
\_\_\_\_\_ to Secretary

RETURN TO ELECTRIC SECTION

UTILITIES DIVISION

SECTION: Electric

R E S O L U T I O N

DATE: March 21, 1955

- \_\_\_\_\_ Director
- \_\_\_\_\_ Numerical File
- \_\_\_\_\_ Alphabetical File
- \_\_\_\_\_ Accounting Officer

SUBJECT:

WHEREAS:

3. Said circuits are not worked on unless the circuits are de-energized and securely grounded, or if energized work shall be done only by means of approved live line tools.

The Secretary is directed to cause appropriate notice to be given said utility of the granting of this permission.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 21st day of March, 1955, the following Commissioners voting favorably thereon:

PETER R. WICKHAM, JUSTON F. ORANER,  
RAY E. DOWENHIZER, MARSHALL J. DODDGE.

*Ed. Glavin*

Secretary

000  
MAR 21 1955