

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

Orig. and Copy  
to Secretary

RESOLUTION NO. 5-973

UTILITIES DIVISION

SECTION: Electric

DATE: March 3, 1958

R E S O L U T I O N

Director  
✓ Numerical File  
Alphabetical File  
Accounting File

SUBJECT: Permission to Deviate from Rule 58.3-C3 of General Order No. 95 by Grounding Transformer Case in Experimental Test of Plastic Transformer Case Cover Material

WHEREAS: SAN DIEGO GAS & ELECTRIC COMPANY has by letter dated January 7, 1958, requested permission to deviate from Rule 58.3-C3 of General Order No. 95 by grounding a transformer case in an experimental test of a plastic transformer case cover under salt, fog and sun conditions at Imperial Beach, and,

WHEREAS: Such grounding of a transformer case would be in violation of Rule 58.3-C3 of General Order No. 95 and

WHEREAS: The grounding of the case is necessary since the only type of mold manufactured at present is for a single-bushing transformer with a grounded case, and good cause appearing,

IT IS HEREBY ORDERED that San Diego Gas & Electric Company be granted permission to deviate from the provisions of Rule 58.3-C3 of General Order No. 95 by the grounding of an experimental transformer case under the following conditions:

1. The grounding of this transformer case is for the sole purpose of testing the bushing and plastic transformer case cover material under salt, fog and sun conditions.
2. Warning signs readily legible from the climbing space shall be placed on the pole, indicating that the transformer case is grounded, that the transformer is installed for experimental purposes only, and indicating switches to be opened before work may be done on the transformer station.
3. The authority herein granted shall expire one year from the date of installation, unless a longer period may be authorized following a written request therefor by said company.
4. Said company promptly shall advise the Commission of the date of installation.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 3rd day of March, 1958, the following Commissioners voting favorably thereon:

PETER E. MITCHELL  
RAY E. UNTEREHRNER  
MATTHEW J. DOOLEY

  
Secretary