

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

Orig. and Copy
to Secretary

Director
 Numerical File
 Alphabetical File
 Accounting Officer

R E S O L U T I O NRESOLUTION NO. **E-977**

UTILITIES DIVISION
 SECTION: **Electric**
 DATE: **4-1-58**

SUBJECT: **Permission to Occupy Both Sides of a Thoroughfare
 with Class "H" Circuits**

The SOUTHERN CALIFORNIA EDISON COMPANY has, by letter dated ~~MARCH 17~~, 1958, requested authorization to occupy both sides of Los Nietos Road, in the County of Los Angeles, near Santa Fe Springs, with Class "H" circuits, a distance of approximately 2,700 feet, and

WHEREAS: Permission for such occupancy is required by Rule No. 31.3 of General Order No. 95, and

WHEREAS: The General Telephone Company of California, the communications utility in the area, by letter dated March 10, 1958, stated that it has no objection to the proposed construction provided instantaneous trip relays are installed in the power circuit involved (The Mills Circuit) which would cause it to be de-energized in approximately four cycles' time duration (0.067 seconds) in the event that contact were made between one of the Class "H" conductors and the grounded communication aerial plant,

IT IS FOUND that the requested permission should be granted and good cause appearing,

IT IS HEREBY ORDERED that permission be granted the Southern California Edison Company under the provisions of Rule No. 31.3 of General Order No. 95 to occupy with Class "H" circuits on both sides of Los Nietos Road, in the County of Los Angeles, near Santa Fe Springs, a distance of approximately 2,700 feet west from Santa Fe Springs Road to Dice Road, as shown on J.P. Authorization plan map No. E 6047-5707 dated March 3, 1958, submitted with the company's letter of March 17, 1958, provided instantaneous trip relays are installed in the power circuit involved which will de-energize said circuit within approximately four cycles' (0.067 seconds) time duration in the event of a contact between said circuit and the grounded communication aerial plant jointly supported on said Class "H" lines.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 1st day of April, 1958, the following Commissioners voting favorably thereon:

PETER E. MITCHELL
 RAY E. UNTEREINER
 MATTHEW J. DOOLEY

C. LYN FOX


 Secretary