

## PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

Orig. and Copy  
to Secretary

RESOLUTION NO.

E-1003

R E S O L U T I O N

UTILITIES DIVISION

SECTION: ElectricDATE: October 15, 1958\_\_\_\_\_  
Director\_\_\_\_\_  
Numerical File\_\_\_\_\_  
Alphabetical File\_\_\_\_\_  
Accounting FileSUBJECT: Permission to Deviate from Rule 44.1 of General Order No. 95  
with Respect to Safety Factor of Certain Poles

WHEREAS: THE PACIFIC TELEPHONE AND TELEGRAPH COMPANY has, by letter dated July 5, 1957, requested permission to deviate from the safety factor requirements of Rule 44.1 of General Order No. 95 in the case initial installation of eight jointly-used poles set on an experimental basis in the subdivision known as "Montgomery Village", Santa Rosa, and

WHEREAS: Rule 44.1 of General Order No. 95 does not provide for such safety factors at the time of initial installation, yet the safety factor for such poles is reported to be greater than that required for their replacement, and

WHEREAS: It appears that safety to workmen and the public will not be lessened by the continuance in service of these poles on an experimental basis, and that the requested permission should be granted, and good cause appearing,

IT IS HEREBY ORDERED that The Pacific Telephone and Telegraph Company and Pacific Gas and Electric Company be authorized to deviate from the initial safety factor provisions of Rule 44.1 of General Order No. 95 by continuing in service each of eight jointly-used poles in the subdivision known as Montgomery Village, Santa Rosa, California, which poles were initially set with safety factors less than required by said rule but with safety factors greater than the minimum value permitted without replacement by Rule 44.2 of said order, during the period when the strength of any of such poles remains above the replacement value calculated by use of the minimum safety factor set forth in Rule 44.2.

The Secretary is hereby directed to cause appropriate notice to be given The Pacific Telephone and Telegraph Company and Pacific Gas and Electric Company of the granting of this authorization.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 15th day of October, 1958 the following Commissioners voting favorably thereon:

President  
PETER H. MEECHAM  
RAY E. UNDERHILL  
MATTHEW J. DOOLEY  
THEODORE H. JENNEN  
Commissioners

  
Secretary