

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

RESOLUTION NO. **E-1016**

Copy for:

Orig. and Copy
to Secretary

R E S O L U T I O N

UTILITIES DIVISION
SECTION: **Electric**
DATE: **February 24, 1959**

Director

Numerical File

Alphabetical File

Accounting File

SUBJECT: **Permission to Deviate from Rule 92.1-F of General Order No. 95 with Respect to Clearance between Transformer Case and Television (Communication) Cable**

WHEREAS: **THE BLYTHE T.V. CABLE SYSTEM, by letter dated July 7, 1958 requested permission to deviate from Rule 92.1-F of General Order No. 95, with regard to vertical clearance of 40 inches between a transformer case and a television cable at four pole locations only, and**

WHEREAS; **It is impractical to obtain the vertical clearance and in lieu of this vertical clearance, a horizontal clearance of 3 feet and a vertical clearance of 1-foot from the transformer case is required which will provide adequate climbing and working space, and**

WHEREAS: **The California Electric Power Company, owners of the transformer pole structures, by letter December 11, 1958, approved such clearances.**

IT IS HEREBY ORDERED that permission be granted The Blythe T.V. Cable System to deviate from the vertical provisions of Rule 92.1-F(1) at four locations, namely in the alley north of Hobson Way: the pole west side of Broadway, the two poles west of Spring St., and the pole west of Main St., provided the television cable is not less than 1-foot vertically below and 3 feet horizontally from the plane of the nearest surface of the transformer case.

C. LYN FOX

President

PETER E. MITCHELL


MATTHEW J. DOOLEY

THEODORE H. JENNER

EVERETT C. McKEAGE

Commissioners

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular session of the Public Utilities Commission of the State of California, held on the 24th day of February, 1959, the following Commissioners voting favorably thereon:


Secretary