

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

*

Copy for:

Orig. and Copy

to Secretary

RESOLUTION NO. G-1324

UTILITIES DIVISION

BRANCH/SECTION: Gas

DATE: June 1, 1966

RESOLUTION

.....Director

.....Numerical File

.....Alphabetical File

.....Accounting Officer

SUBJECT: Request for Deviation From G. O. 58-A
Pacific Gas and Electric Company

WHEREAS: PACIFIC GAS AND ELECTRIC COMPANY has by letter dated May 13, 1966, requested a deviation from Rule 24(a) of General Order No. 58-A which requires that no gas meter shall be allowed to remain in service more than 10 years from the time when last tested without being retested. The Company proposes to retain in service until July 1, 1967, 55,881 meters which would be removed in 1966 under Rule 24(a). Sampling of these meters indicates that less than 10% are registering more than 2% fast.

WHEREAS: The deviation will expedite the removal, testing, and adjusting of groups of meters which are more than 2% fast, and good cause appearing,

IT IS ORDERED that Pacific Gas and Electric Company is hereby authorized to deviate from Rule 24(a) of General Order No. 58-A under the conditions of its letter dated May 13, 1966, until July 1, 1967.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular conference of the Public Utilities Commission of the State of California, held on the.....1st.....day of.....June....., 1966....., the following Commissioners voting favorably thereon:

FREDERICK B. HOLBOFF, President
..... GEORGE G. GROVER,
..... WILLIAM M. BENNETT, A. W. GATOV,
Commissioners

William W. Dunlop
.....
Secretary