

PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Copy for:

RESOLUTION NO. G-1381

..... Orig. and Copy  
..... to Secretary

RESOLUTION

UTILITIES DIVISION  
BRANCH/SECTION: GAS  
DATE: June 27, 1967

..... Director  
..... Numerical File  
..... Alphabetical File  
..... Accounting Officer

SUBJECT: Request for Deviation from General Order No. 58-A  
Pacific Gas and Electric Company

WHEREAS: PACIFIC GAS AND ELECTRIC COMPANY has by letter dated June 16, 1967, requested a deviation from Rule 24(a) of General Order No. 58-A which requires that no gas meter shall be allowed to remain in service more than 10 years from the time when last tested without being retested; and

WHEREAS: The company proposes to retain in service approximately 40,000 meters installed in 1956 where sample tests of meter groups indicate that less than 10% are registering more than 2% fast; and

WHEREAS: The company proposes to retain in service approximately 92,500 meters which would be removed in 1967 under Rule 24(a) while removing from service approximately 98,200 meters which have been in service 10 years and less; and

WHEREAS: The deviation will expedite the removal, testing, and adjusting of groups of meters having more than 10% of the meters more than 2% fast, and good cause appearing,

IT IS ORDERED that Pacific Gas and Electric Company is hereby authorized to deviate from Rule 24(a) of General Order No. 58-A, under conditions of its letter dated June 16, 1967, until July 1, 1968.

I hereby certify that the foregoing Resolution was duly introduced, passed and adopted at a regular conference of the Public Utilities Commission of the State of California, held on the 27th day of June, 1967, the following Commissioners voting favorably thereon:

PETER E. MITCHELL  
President  
WILLIAM M. BENNETT  
A. W. GATOV  
WILLIAM SYMONS, JR.

*William W. Dwyer*

Secretary